

NSP

NORTHERN STATES POWER COMPANY

MINNEAPOLIS, MINNESOTA 55401

June 8, 1979

Director of Nuclear Reactor Regulation
U S Nuclear Regulatory Commission
Washington, DC 20555

PRAIRIE ISLAND NUCLEAR GENERATING PLANT
Docket No. 50-282 License No. DPR-42
50-306 DPR-60

Information Required for NRC Review of Inservice
Inspection and Testing Program and Requests for Relief from
ASME Code Section XI Requirements

Attached you will find 40 copies of Revision Number 2 to our report entitled, "ASME Code Section XI Inservice Inspection and Testing Program and Information Required for NRC Review of Requests for Relief from ASME Code Section XI Requirements." This is a revision of our inservice inspection and testing program description and requests for relief submitted to the Commission on February 1, 1978.

The purpose of this revision is to:

- (a) Remove the waste gas system from the Section XI Inservice Inspection and Testing Program as requested by the NRC Staff. This change affects 13 Code classification drawings, deletes testing requirements for several valves, deletes pressure tests of piping, and deletes Requests for Relief 6 and 38 for both units.
- (b) Remove testing requirements for three boundary valves having no safety function.
- (c) Revise Request for Relief 59 for both units in an attempt to meet NRC Staff guidelines on leakage testing.
- (d) Add Requests for Relief 61 and 62 for both units. These Requests delete valve exercise tests during plant operation in two cases where the tests could have an adverse effect on plant equipment and safety.
- (e) Correct typographical errors.

2308 054

7906190342

NORTHERN STATES POWER COMPANY

Director of Nuclear Reactor Regulation
Page 2
June 8, 1979

Instructions are provided for entering Revision Number 2 in the original February 1, 1978 report. Please contact us if you have any questions related to this revision.

L O Mayer

L O Mayer, PE
Manager of Nuclear Support Services

LOM/DMM/ak

cc: J G Keppler
G Charnoff

Attachment

2308 055