(7-77)

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | N C B E P 1 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
01 | REPORT SOURCE L (6) | 0 5 0 - 0 3 2 5 (7) | 0 6 0 2 7 9 (8) | 0 6 2 8 7 9 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 While performing an inspection of pipe supports and hangers in accordance with I. E.
03 Bulletin 79-07, the following snubbers were found inoperable:
04 1) 1G41-12SS9B, RHR discharge to fuel pool cooling; 2) 1E21-2SS31, Core Spray line to
05 vessel; 3) 1B21-44SS138, vessel head vent; 4) 1E11-90SS275, vessel head spray;
06 5) 1PSN-D3SS71, main steam line 'D'.
07 (Technical Specification 3.7.5,6.9.1.9b)
08

09 SYSTEM CODE S H (11) | CAUSE CODE X (12) | CAUSE SUBCODE X (13) | COMPONENT CODE S U P O R T (14) | COMP. SUBCODE D (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 7 9 | — | SEQUENTIAL REPORT NO. 0 3 6 | / | OCCURRENCE CODE 0 3 | REPORT TYPE L | — | REVISION NO. 0

ACTION TAKEN X (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0 0 0 0 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. Y (24) | PRIME COMP. SUPPLIER A (25) | COMPONENT MANUFACTURER B 2 0 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 1E21-2SS31 had slipped due to a nut coming loose on the hanger belt. The snubber was
11 aligned and the nut tightened per procedure. The other four snubbers had a low fluid
12 level due to leaking seals. The snubbers were rebuilt, functionally tested, and re-
13 turned to service. Snubber inspections will continue per Technical Specifications.
14

15 FACILITY STATUS G (28) | % POWER 0 0 0 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY C (31) | DISCOVERY DESCRIPTION (32) Hanger Inspection

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

17 PERSONNEL EXPOSURES: NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) NA

18 PERSONNEL INJURIES: NUMBER 0 0 0 (40) | DESCRIPTION (41) NA

19 LOSS OF OR DAMAGE TO FACILITY (43): TYPE Z (42) | DESCRIPTION NA

7907050329

20 PUBLICITY: ISSUED N (44) | DESCRIPTION (45) NA

NRC USE ONLY

289 060

NAME OF PREPARER A. C. Tollison, Jr. PHONE: 919-457-9521