



UNITED STATES
ATOMIC ENERGY COMMISSION
WASHINGTON, D.C. 20545

50-2.1

JAN 20 1971

J. P. O'Reilly, Chief
Inspection and Enforcement Branch
Division of Compliance

VENDOR INSPECTION REPORT - GRINNELL COMPANY (70/2)

The enclosed report of an inspection of the Grinnell Company, Warren, Ohio on November 17-18, 1970, is forwarded for information. The purpose of the inspection was to examine piping assemblies for the Metropolitan Edison Company's Three Mile Island, Unit 1, reactor. The assemblies and work inspected were found to be satisfactory.

We continue to be concerned about this major piping fabricator not having code stamp authorization under the ASA B31.7 Code. However, for the specific piping examined during this inspection, no code stamp was required; thus, we are unable to take enforcement action at this time. We will continue our surveillance of this fabricator during 1971.

G. W. Reinmuth
Senior Reactor Inspection
Specialist
Division of Compliance

Enclosure:
Grinnell Co. - 70/2

cc w/enclosure:

E. G. Case, DRS (3)
P. A. Morris, DRL
R. S. Boyd, DRL (2)
R. C. DeYoung, DRL (2)
D. J. Skovholt, DRL (3)
P. W. Howe, DRL (2)

A. Giambusso, CO
L. Kornblith, Jr., CO
R. H. Engelken, CO
Regional Directors, CO
REG Files
W. E. Vetter, CO:III

1483 144

7910170 955