POOR ORIGINAL

JAN 12 1973

R. C. DeYoung, Assistant Director for PWR's, L

RESPONSE TO REVIEW PLAN ASSIGNMENT - THREE MILE ISLAND NUCLEAR STATION, UNIT 1, REVIEW OF DRAFT SAFETY EVALUATION REPORT

Plant Name:	Three Mile Island Unit 1
Licensing Stage:	OL
Docket No.:	50-289
Branch & Project Manager Requesting Assistance:	L:PWR-2, H. E. Schierling
Technical Review Branch Involved:	L:OSB
Requested Completion Date	1/18/73
Description of Review:	Review of SER and Unresolved Items
Review Status:	Revisions required by applicant.

As requested info mally work has been completed on the functional review identified in the block above. Our conclusions are contained in the attached report.

Original Signed by
Donald F. Knuth

D. F. Knuth, Assistant Director
for Reactor Safety
Directorate of Licensing

cc w/encl:
S. H. Hanauer, DRTA
J. M. Hendrie, L:TR
K. Kniel, L:PWR-2
H. E. Schierling, L:PWR-2
R. W. Houston, L:OSB
C. R. Van Niel, L:OSB

cc w/o encl:
W. McDonald, L:OPS

1483 329

OFFICE ▶	L:OSB	L:OSB	L:TR			
SURNAME ▶	CRVanNiel:cl	RWHouston	DFKnuth			
DATE ▶	1/9/73	1/9/73	1/ 11/73			

Form AEC-318 (Rev. 9-53) AECM 0240 ☆ U. S. GOVERNMENT PRINTING OFFICE 1972—466 783

7910171020 E

Three Mile Island Nuclear Station Unit 1
Docket 50-289

A review of the list of Unresolved Items (12/19/72) and the draft safety evaluation report (12/21/72) has been completed. The action required of the applicant is specified below.

1. Table II, Item 9, Industrial Security Plan

   The Plan should be revised as follows:

   Page 5, Section 2.2.6, second paragraph, second sentence. Change "weekly" to "daily."

   Page 7, fourth paragraph. State the provisions for escorting delivery personnel inside the security fence, either by security, warehouse, or operating personnel.

   Page 8, first paragraph. State what actions will be taken by the onsite security force to apprehend an intruder or foil an intrusion attempt, while awaiting the arrival of the State Police. (See ANS 3.3, section 3.3.4 and 3.4.4)

   Page 5. Add a new section 2.2.6, "Surveillance of Vital Equipment and Facilities." Discuss the provisions for such surveillance. (See ANS 3.3, section 3.4.3)

2. Table II, New Item 17, Emergency Plan

   A revision to the FSAR is needed which will include:

   a. Written agreements with offsite support groups.

   b. The designation of alternates during an emergency (succession of command).

3. Draft Safety Evaluation Report

   Section 13.5, last sentence. Deleted remainder of sentence following "...from the applicant."