

# CENSEE EVENT REPORT

CONTROL BLOCK: 

--	--	--	--	--	--

(PLEASE PRINT ALL REQUIRED INFORMATION)

LICENSEE NAME: 

01	P	A	T	M	I	1
----	---	---	---	---	---	---

 LICENSE NUMBER: 

0	0	-	0	0	0	0	0	-	0	0
---	---	---	---	---	---	---	---	---	---	---

 LICENSE TYPE: 

4	1	1	1	1
---	---	---	---	---

 EVENT TYPE: 

0	1
---	---

CONT: 

0	1
---	---

 CATEGORY: 

--	--

 REPORT TYPE: 

T
---

 REPORT SOURCE: 

L
---

 DOCKET NUMBER: 

0	5	0	-	0	2	8	9
---	---	---	---	---	---	---	---

 EVENT DATE: 

0	5	2	3	7	7
---	---	---	---	---	---

 REPORT DATE: 

0	6	0	6	7	7
---	---	---	---	---	---

### EVENT DESCRIPTION

02 | During normal operation the TSS concentration of the river water discharge was  
03 | found to be in excess of the designated maximum. Redundant systems were not  
04 | available for this repetitive occurrence. The discharge was immediately terminated,  
05 | steps will be taken to repair the sample pipe which was found to be leaking. (77-13/4T)  
06 |

SYSTEM CODE: 

Z	Z
---	---

 CAUSE CODE: 

F
---

 COMPONENT CODE: 

Z	Z	Z	Z	Z	Z
---	---	---	---	---	---

 PRIME COMPONENT SUPPLIER: 

Z
---

 COMPONENT MANUFACTURER: 

Z	9	9	9
---	---	---	---

 VIOLATION: 

N
---

### CAUSE DESCRIPTION

08 | A slug of suspended solids could have broken loose during sampling and provided  
09 | a sample with a TSS concentration greater than the representative effluent.  
10 |

FACILITY STATUS: 

E
---

 % POWER: 

1	0	0
---	---	---

 OTHER STATUS: 

NA
----

 METHOD OF DISCOVERY: 

A
---

 DISCOVERY DESCRIPTION: 

NA
----

  
FORM OF ACTIVITY RELEASED: 

Z
---

 CONTENT OF RELEASE: 

Z
---

 AMOUNT OF ACTIVITY: 

NA
----

 LOCATION OF RELEASE: 

NA
----

### PERSONNEL EXPOSURES

13 | NUMBER: 

0	0	0
---	---	---

 TYPE: 

Z
---

 DESCRIPTION: 

NA
----

### PERSONNEL INJURIES

14 | NUMBER: 

0	0	0
---	---	---

 DESCRIPTION: 

NA
----

### OFFSITE CONSEQUENCES

15 | 

NA
----

### LOSS OR DAMAGE TO FACILITY

16 | TYPE: 

Z
---

 DESCRIPTION: 

NA
----

### PUBLICITY

17 | Included in the Weekly News Release

### ADDITIONAL FACTORS

18 |

19 |

1482 079

NAME: W. E. Potts

PHONE: 929-3601 (ext. 114)

7910250 798 GPO 881-667