

MAR 17 1975

Docket No. 50-289

Metropolitan Edison Company  
ATTN: Mr. R. C. Arnold  
Vice President - Generation  
P. O. Box 542  
Reading, Pennsylvania 19603

DISTRIBUTION:

NRC PDR  
Local PDR  
Docket  
ORE#3 Rdg  
KRGoller  
TJCarter  
Glear  
fe  
ets  
OF D  
SIGE (3)  
ACRS (14)  
Gray file  
extra cps (5)

Gentlemen:

In a letter to Mr. R. C. Arnold dated July 26, 1974 we requested that you submit an analysis to demonstrate the acceptability of the reactor building spray pump motors. In response to this request you submitted calculations on September 13 and September 30, 1974 via letters to Mr. A. Schwencer.

Our review of your calculations indicates that the reactor building spray pump motors have the ability to perform their intended function with a degraded offsite power supply. We therefore find the reactor building spray pump motors acceptable.

Sincerely,

Original Signed

George Lear, Chief  
Operating Reactors Branch #3  
Division of Reactor Licensing

cc: See next page

1485 231

OFFICE	ORB#3	ORB#3				
SURNAME	DLJaffe:kmi	Glear				
DATE	3/11/75	3/17/75				

7910260690 p

Mr. R. C. Arnold

- 2 -

cc: G. F. Trowbridge, Esquire  
Shaw, Pittman, Potts, Trowbridge & Madden  
Barr Building  
910 17th Street, N. W.  
Washington, D. C. 20006

GPU Service Corporation  
Richard W. Heward, Project Manager  
Thomas M. Crimmins, Jr., Safety  
and Licensing Manager  
260 Cherry Hill Road  
Parsippany, New Jersey 07054

Pennsylvania Electric Company  
Vice President, Technical  
1001 Broad Street  
Johnstown, Pennsylvania 15907

Mr. Weldon B. Arehart, Chairman  
Board of Supervisors of Londonberry  
Township  
2148 Foxiana Road  
Middletown, Pennsylvania 17057

Miss Mary V. Southhard, Chairman  
Citizens for a Safe Environment  
P. O. Box 405  
Harrisburg, Pennsylvania 17108

Government Publications Section  
State Library of Pennsylvania  
Box 1601 (Education Building)  
Harrisburg, Pennsylvania 17126

1485 232

OFFICE ➤						
SURNAME ➤						
DATE ➤						