

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

January 24, 1980

Director of Nuclear Reactor Regulation
Attention: Mr. L. S. Rubenstein, Acting Chief
Light Water Reactors Branch No. 4
Division of Project Management
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Dear Mr. Rubenstein:

In the Matter of the Application of) Docket Nos. 50-327
Tennessee Valley Authority) 50-328

On January 16, 1980, a meeting was held at Sequoyah Nuclear Plant with NRC-NRR Consultant R. M. Gustafson and TVA employees to discuss welds on pressurizer relief piping. During this meeting, Mr. Gustafson requested additional information which was not available at the plant site. Enclosed is the requested information.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

L. M. Mills

L. M. Mills, Manager
Nuclear Regulation and Safety

Enclosure

1816 039

*Bool
SE 1/1*

8001280

251

ADDITIONAL INFORMATION ON PRESSURIZER RELIEF LINE
DRAW BEAD ALIGNMENT WELDS

A meeting was held on January 16, 1980, between Roy Gustafson of NRC-NRR and several TVA design and construction personnel. The following information was provided to Mr. Gustafson concerning the draw bead alignment welds on the pressurizer relief line:

1. A drawing of the weld area.
2. The welding procedure and the procedure qualification.
3. Results of the Strauss test performed on a mockup.
4. Westinghouse specifications on water chemistry.
5. Pipe bending procedure.
6. The UT baseline scan for each weld.
7. Certified material test report (CMTR) for the pipe.
8. Special instructions from Engineering Design for this particular weld bead alignment.
9. NDE results.

In addition, Mr. Gustafson requested information that was not available at the time of the meeting. The requested information is contained in the following discussion.

Circumstances Requiring Use of Draw Bead and Discussion of Stress Analysis

During the hot functional test, a pipe support providing restraint in the lateral direction failed to slide as designed, restraining the pipe in the vertical direction. The restraint is located at joint 33 shown on the sketch in enclosure 1. A copy of the restraint design is shown in enclosure 2.

The maximum anticipated vertical movement at joint 33 during normal operation was anticipated to be 2.87 inches assuming a worst case operating temperature of 653° F. The hot functional test had proceeded to an operating temperature of approximately 550° F at the time of discovery of the bound up support. The U-bolt which restrained the pipe in the vertical direction was deflected approximately one inch vertically.

In order to determine the stress levels due to the bound support, an analysis was run with the piping at 550° F and a vertical restraint installed at joint 33. The vertical restraint was free for the one-inch vertical movement simulating the one-inch deformation of the U-bolt. The stress levels for the joints shown in enclosure 1 are tabulated in enclosure 3. These stress levels are below the ASME, Section III allowable stress for nonrepeated stresses as defined by NC-3611.2(f). That allowable stress for A-376T316 is 60,000 lb/in². Pressurizer relief nozzle loads for this anomaly load case were forwarded to Westinghouse for review by enclosure 4 and were approved by enclosure 5.

Enclosure 6 gives maximum stress at node 13A during plant operation for occasional loads. Node 13A is within five inches of both draw beads.

1816 040

POOR ORIGINAL

Residual Stresses

Residual stresses are considered to be no greater than the stresses in a repair to base metal or in any other weld in the system. The nature of these stresses at the inside diameter (id) induced by welding are considered to be compressive due to the technique used and consequently will not adversely affect the material's susceptibility to stress corrosion cracking (IGSCC). Compressive stresses are known to have a mitigating effect on IGSCC; thus, we do not have stresses which can cause IGSCC.

Heat Input Calculation for Draw Bead Repair

1. Maximum heat input used on the preproduction mockup which passed a Strauss test.

$$\text{Amps} = 160\text{A}$$

$$\text{Volts} = 14\text{V}$$

$$\text{Travel Speed} = 3/4 \text{ in/min} = \text{TS}$$

$$\begin{aligned} \text{Heat input per inch} &= \frac{\text{Amps} \times \text{Volts} \times 60}{\text{Travel Speed in/min}} \\ &= \frac{14\text{V} \times 160\text{A} \times 60}{0.75 \text{ in/min} \times 1000} \\ &= 179.2 \text{ kilojoules} \end{aligned}$$

2. Actual heat input used for production welding.

$$\text{Amps} = 90\text{A}$$

$$\text{Volts} = 11\text{V}$$

$$\text{TS} = 2 \text{ in/min}$$

$$\begin{aligned} \text{Heat input per inch} &= \frac{11\text{V} \times 90\text{A} \times 60}{2 \text{ in/min} \times 1000} \\ &= 29.7 \text{ kilojoules} \end{aligned}$$

Thus, it can be seen that the actual heat input for each draw bead is well within considered acceptable limits.

Anticipated Oxygen Content

Area of concern is located in the 6-inch, schedule 160, vertical pipe run leading to the pressurizer relief valve at an elevation approximately level with the top of the pressurizer. The environment is saturated steam at 650° F and 2485 lb/in².

1816 041

Based on the best information available to us from Westinghouse and operating utilities:

1. Maximum oxygen content in the reactor coolant water is controlled to less than 0.1 p/m at temperatures above 180° F by scavenging with hydrazine.
2. During power operation, the residual oxygen concentration will not exceed 0.005 p/m.
3. The highest calculated oxygen concentration expected in the steam is less than 0.2 p/m.
4. EPRI information gives 6 p/m as the threshold value below which IGSCC will not occur in 316 stainless steel (reference GE report No. NEDC-23750-6 dated November 1979, "Alternate Alloy for BWR Pipe Applications, Third Semiannual Progress Report."

It may therefore be concluded that the oxygen environment is not sufficient to produce IGSCC.

Summary

Based on the foregoing discussion and the information given to Mr. Gustafson at the Sequoyah meeting, the following conclusions may be reached:

1. Intergranular stress corrosion cracking (IGSCC) will not occur because:
 - a. Satisfactory results of an ASTM A262, Practice E test, on a mockup of a worst case situation indicates that the material (316 stainless steel in the existing condition) is not susceptible to IGSCC.
 - b. Residual stresses produced in the weld area will be compressive and, consequently, will not contribute to IGSCC.
 - c. Environment for IGSCC does not exist due to low oxygen concentration.
2. Stresses produced by the draw bead technique are considered to be equivalent to those in any other weld in the system and do not adversely affect the Sequoyah piping analysis.

TVA concludes that the subject condition will not compromise safe operation of the plant. Furthermore, we have met or exceeded all licensing and code commitments for Sequoyah.

1816 042

Enclosure 1

SUBJECT SQNP - Pressurizer Relief PROJECT

Piping Sketch


COMPUTED BY

DATE

CHECKED BY

DATE



PRESSURIZER RELIEF PIPING SKETCH



1816 043

CALLING CODE Y
 DESIGNED AND DETAILED BY EDS
 CONTRACT NO. T42499A
 TVA APPROVED
 NOV 7 1958

CUSTOMER: SEQUOYAH NUCLEAR PLANT UNIT # 1
 PIPING CONT. NAVCO, TVA 71-23-25615
 ITEM NO. 1
 SERVICE: REACTOR COOLANT



1816 044

13-03 REV. 0 PT. 3

DESIGN LOAD	+	-
Fx Lbs.	5960	1320
Fy Lbs.	-	-
Fz Lbs.	13,030	2910

1	EFF	1/2 RC V
2	W	2-1 W-RC


ISO. NO. 44-2225 Area: 150 NUCLEAR T.V.A. CLASS "A"
 CHKO. REF. DWGS.
 BASIC ENGINEERS
 PITTSBURGH, PENNSYLVANIA 15221
 DIVISION OF NATIONAL VALVE AND MANUFACTURING CO.

FILE PRINT
 S.O. 82-4150-120
 CHECKED: 11-1-58

CUSTOMER: SEQUOYAH NUCLEAR PLANT UNIT # 1
 PIPING CONF. NAVCO, TVA 71CBB-92615
 ITEM NO. 1


SERVICE:
 REACTOR COOLANT

E.I. APPROVED
 FOR CONSTRUCTION



SECTION C-C

POOR ORIGINAL



DETAIL A

1816 045

BILLING COPY
 DESIGNED AND DRAWN BY EDS
 CONTRACT NO. T142482A

TVA APPROVED
 DATE 7 1973

DATE: 7/19/73 SHEET: 1 OF 1	CHECKED: [] DATE: []	P.E. DWGS. 71CBB-92615-1 BASIC ENGINEERS PITTSBURGH, PENNSYLVANIA 15201 DIVISION OF NATIONAL VALVE AND MANUFACTURING CO.	S.O. 55-1160-12 SHEET 1-93
--------------------------------	---------------------------	---	-------------------------------

CUSTOMER: SEQUOYAH NUCLEAR PLANT UNIT # 1 PIPING CONT. NAVCO, TVA 71638-92515 ITEM NO. 1	SERVICE: REACTOR COOLANT
--	--------------------------

MATERIAL AND OPERATIONS FOR	6"	MK. NO. 1-RCH-93	ASSEMBLIES REQUIRED 1
-----------------------------	----	------------------	-----------------------

PCS.	FOR	WT.	UNIT	PRICE
	HORIZONTAL RESTRAINT.			
2	1/2" C.S. STIFFENER PLATES FOR 11-0" LG.	⊙ □		
10	1/2" C.S. STIFFENER PLATES FOR 11-1/2" LG.	⊙ □		
1	1/2" C.S. STIFFENER PLATE FOR EXIST. 11-11" LG.	⊙ □		
2	1/2" C.S. STIFFENER PLATES FOR EXIST. 11-11" LG.	⊙ □		
1	1/2" x 10 1/4" C.S. PLATE, 11-8" LG.	⊙ □		
2	2E-101, 1/8" φ 1 1/2" C. & P. PIPE, D=7 1/4" E=8", C=7-1/2", V/12 - 1/8" φ HEX NUTS 2'-2 1/2" LG. SPEC. BEND	□ △		
1	5" x 6" C.S. PLATE, FIELD TO DETERMINE THICKNESS	⊙ □ △		
BY TVA				
□ PAINT CARBO-WELD 11 PRIMER BY TVA				

POOR ORIGINAL

1816 046

DRWN DATE	CHKD. DATE	REF. DWG. NO.	FILE NO.
11/1/53	11/1/53	11-11-53	11-11-53
BASIC ENGINEERS PITTSBURGH, PENNSYLVANIA 15201 DIVISION OF NATIONAL VALVE AND MANUFACTURERS CO.		S.O. 11-11-53-120 SHEET 1-11-53-93	

BILLING COPY
 DESIGNED AND DETAILED BY GUS
 CONTRACT NO. 71638-92515
 TVA APPROVED
 DATE 11/1/53

REVISIONS
 FOR CONSTRUCTION

Enclosure 3

Table of Stress Levels

<u>Joint</u>	<u>Stress</u>	<u>Allowable Stress</u>
32	38,215	60,000
33	41,300	60,000
35	18,283	60,000
38	27,083	60,000
38A	23,648	60,000
39	24,754	60,000
40	17,064	60,000

1816 047

Enclosure 4

TENNESSEE VALLEY AUTHORITY
KNOXVILLE, TENNESSEE 37902
W10C126,400 Commerce Avenue

PCOR ORIGINAL

May 30, 1979

MEB '79 0529 120

Westinghouse Electric Corporation
Post Office Box 355
Pittsburgh, Pennsylvania 15230

Attention: Mr. M. A. Siano

Gentlemen:

SEQUOYAH NUCLEAR PLANT
NUCLEAR STEAM SUPPLY SYSTEMS
CONTRACT 68C60-91934
LETTER NO. 6349

NOZZLE LOADS APPLIED TO UNIT 1 PRESSURIZER RELIEF LINE NOZZLE (SO 145-01) -
NZM-2-6(CI)

During hot functional testing at Sequoyah one of the supports on the pressurizer relief piping seized and would not permit free movement of the pipe; therefore, some yielding occurred in the piping. We have calculated moments and forces for the pressurizer nozzle for the temperature transient which resulted in the bend pipe. The pipe was assumed to act elastically; therefore, we believe that these loads are conservative.

Please review for acceptability the following nozzle loads which are in local coordinates.

Fx(Lbs)	Fy(Lbs)	Fz(Lbs)	Mx(Ft-Lbs)	My(Ft-Lbs)	Mz(Ft-Lbs)
-442	-16,302	993	-20,357	858	-13,664

Your expedient reply will be appreciated.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

Original signed by
L. H. Chin

D. R. Patterson, Chief
Mechanical Engineering Branch

cc: Mr. R. E. Lyman

5/24

1816 048

Enclosure 5

TVA-7495

DRP	EGG
AR	CAC
	JAN



MFB'79 06 13 566

Water Reactor Divisions

Nuclear Technology Division
Box 355
Pittsburgh Pennsylvania 15230

June 4, 1979
TVA Contract No. 58C60-9193;
MMT-ST-312
S.O. TVA/TEN-130

POOR ORIGINAL

4

Ref.: 1) Letter No. 6349.

NAR

Westinghouse Electric Corporation

Mr. D. R. Patterson, Chief
Mechanical Engineering Branch
TENNESSEE VALLEY AUTHORITY
400 Commerce Avenue, 110 C126
Knoxville, Tennessee 37902

Dear Mr. Patterson:

TENNESSEE VALLEY AUTHORITY
SEQUOYAH NUCLEAR PLANT
UNIT NUMBERS 1 AND 2

Loads Applied to Unit 1 Pressurizer Relief Nozzle

The loads for the Unit 1 pressurizer relief nozzle presented in the above referenced letter have been evaluated and are acceptable. The loads resulted from a seized relief pipe support during hot functional testing. For the evaluation the loads were compared with the normal and upset condition allowables for primary plus secondary stresses. It was assumed that there would be only one occurrence of this loading condition, therefore, the fatigue life of the nozzle will not be effected.

If you have any questions concerning the evaluation, please contact me.

Very truly yours,
WESTINGHOUSE ELECTRIC CORPORATION

M. A. Siano

M. A. Siano, Manager
Tennessee Valley Authority
Projects

JUN 14 1979

D. R. Patterson - 3L

- cc: R. E. Lyman - 1L
- F. E. Rolsten - 1L
- C. E. Brewer - 1L
- L. H. Mills - 1L

DRP:AH	DRAFT COM.	INFO	DATE
CC:	REPLY	COPY	COPY
EEB, W8C126C-K			
CER, W9C126C-K			
EGB			
CAC			
GFD (2145)			

Handwritten initials

1816 049

Handwritten note: X-4184 6/15/79

MEEDS, E4B37 C-K

MASTED EIB N2M-2-le

ENCLOSURE 6

NODE 13A 1303 STRESSES

	<u>Nominal Stresses lb/in²</u>
1. Blowdown	238
2. Gravity (DW)	159.5
3. Abnormal Thermal W/PRT	1419.5)
4. Normal Thermal	1607.1) Use worst
5. Cold Springing W/PRT	2225.6) thermal and
6. Startup Thermal Mode W/PRT	2446.4) cold spring
7. OBEXY: Loop A Modes 1 to 17	268.3)
8. OBEYZ: Loop A Modes 1 to 17	803.9) Use worst
9. Pressure: Stress @ 2485 lb/in ² design	3,943 lb/in ²

Intensification factor is 1.8 for butt weld.

Sum of all stresses for the above load cases:

$$238 + 160 + 2226 + 2447 + 804 + 3943 = 9818 \text{ lb/in}^2 \text{ nominal}$$

$$9818 \times 1.8 \text{ SIF} = 17,672 \text{ lb/in}^2$$

Allowable = 1.8 Sh for occasional loads

$$\text{Sh for A376 TP 316 at } 650^{\circ} \text{ F} = 6,700 \text{ lb/in}^2$$

$$\begin{aligned} \text{Allowable} &= 1.8 \times 6,700 \text{ lb/in}^2 \\ &= 30,240 \text{ lb/in}^2 \end{aligned}$$

and stresses in this area are acceptable.

1816 050