APPENDIX A

Portland General Electric Company
121 S. W. Salmon Street
Portland, Oregon 97204

Docket No. 50-344
License No. NPF-1

Notice of Violation

Based on the results of NRC inspections conducted during November 1-30, 1979, it appears that one of your activities was not conducted in full compliance with conditions of your NRC Facility License No. NPF-1 as indicated below. This item is an infraction.

> Facility Operating License No. NPF-1 requires in Section 2.C.(7) that "...all activities to which a quality assurance program is applicable shall, after the date of issue of the license, be conducted in accordance with the Quality Assurance Program for Operation."
>
> Contrary to the above, the requirements of Quality Assurance Procedure QAP 12-1, "Installed Instrumentation Calibration Control Program," were not adhered to in that a test gauge not in a current state of calibration was used during the calibration of an installed plant instrument.

1948 215

8002120 144