



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

NRC PDR

DEC 18 1978

Docket No. 50-502

Mr. Sol Burstein
Executive Vice President
Wisconsin Electric Power Company
231 West Milwaukee Street
Milwaukee, Wisconsin 53201

Dear Mr. Burstein:

SUBJECT: FIRST ROUND REQUEST FOR ADDITIONAL INFORMATION CONCERNING
HAVEN NUCLEAR PLANT, UNIT 1

As a result of our review of the Haven 1 Preliminary Safety Analysis Report, we find that we need additional information to continue our evaluation. The specific information required is listed in the Enclosure.

Please provide a response to this request in the amendment to your PSAR scheduled for February 1979.

Please contact us if you desire any discussion or clarification of the Enclosure.

Sincerely,

Olan D. Parr

Olan D. Parr, Chief
Light Water Reactors Branch No. 3
Division of Project Management

Enclosure:
Request for Additional
Information

cc w/enclosure:
See next page

79010203||

B

Mr. Sol Burstein

- 2 -

DEC 18 1978

cc: Gerald Charnoff, Esq.
Shaw, Pittman, Potts & Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

Robert H. Gorske, Esq.
General Counsel
Wisconsin Electric Power Company
780 North Water Street
Milwaukee, Wisconsin 53202

A. William Finke, Esq.
Senior Attorney
Wisconsin Electric Power Company
331 West Michigan Street
Milwaukee, Wisconsin 53201

Thomas A. Lockyear, Esq.
Assistant Chief Counsel
Public Service Commission of Wisconsin
Hill Farms State Office Building
4802 Sheboygan Avenue
Madison, Wisconsin 53702

Mr. Richard L. Prosis
Bureau of Legal Services
Department of Natural Resources
Box 7921
Madison, Wisconsin 53707

Mr. William Charles Hanley
President, Safe Haven Ltd.
P. O. Box 40
Kohler, Wisconsin 53044

Mr. Thomas Galazen
Northern Thunder
Box 334
Turtle Lake, Wisconsin 54888

ENCLOSURE

REQUEST FOR ADDITIONAL INFORMATION

430.0 OPERATOR LICENSING BRANCH

430.3 Amend your PSAR, Section 13.2 to include the fire protection
(13.2) training programs required by Parts I.5 and I.6 of Revision
No. 1 to Standard Review Plan 13.2. Please note that
information contained in Section 9.5.1 of the PSAR does not
necessarily meet the requirements of SRP 13.2.