

APPENDIX A

NOTICE OF VIOLATION

Georgia Power Company

License No. DPR-57

Based on the results of the NRC inspection conducted on November 6-9, 1978, it appears that certain of your activities were not conducted in full compliance with NRC requirements as indicated below. These items have been categorized as described in our correspondence to you dated December 31, 1974.

- A. Technical Specification 6.8.1 requires the licensee to establish, maintain, and implement procedures governing maintenance on safety-related systems. HMP-8, Maintenance Request provides requirements for effecting timely maintenance on systems where plant safety is impaired and/or plant shutdown will be required.

Contrary to the above, a time delay relay fundamental to design operation of the low pressure coolant injection system was found inoperable on April 12, 1978, and not repaired until June 17, 1978. During this time the plant was operated at power on several occasions.

This item is an infraction.

- B. Technical Specification 6.9.1.2.b provides requirements for submitting a written report within 30 days when conditions leading to operation in a degraded mode permitted by a limiting condition for operation are identified.

Contrary to the above, the inoperable time delay relay identified on April 12, 1978, and repaired on June 27, 1978, which resulted in a degradation of the operability of an RHR pump and its associated diesel generator, was not reported to the NRC.

This is a deficiency.

7901180133