

SOUTHEAST UTILITIES



THE SOUTH EASTERN POWER AND LIGHT COMPANY
THE SOUTH EASTERN GAS COMPANY
THE SOUTH EASTERN WATER COMPANY
THE SOUTH EASTERN TELEPHONE COMPANY
THE SOUTH EASTERN CABLE COMPANY
THE SOUTH EASTERN RAILROAD COMPANY

P.O. BOX 270
HARTFORD, CONNECTICUT 06101
(203) 666-6911

February 23, 1979
MP-2-2045

Mr. Boyce H. Grier
Director, Region I
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Reference: Facility Operation License No. DPR-65
Docket No. 50-336
Reportable Occurrence RO-50-336/78-19/3X-1

Dear Mr. Grier:

This letter forwards update Licensee Event Report 78-19/3X-1 pursuant to Millstone Unit 2, Appendix A Technical Specifications, Section 6.9.1.7. The report concerns the inoperability of one of the two emergency diesel generators due to leaking injector pumps.

An additional three copies of the report are enclosed.

Yours truly,

A handwritten signature in cursive script, appearing to read 'J. F. Opeka'.

J. F. Opeka
Station Superintendent
Millstone Nuclear Power Station

JFO/RAS:11m

Attachment: LER 78-19/3X-1

cc: Director, Office of Inspection and Enforcement, Washington, D.C.
(30)
Director, Office of Management Information and Program Control,
Washington, D.C. (3)

7903010 266