(7-77)

LICENSEE EVENT REPORT

CONTROL BLOCK: [ ] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | MNPI N2 (2) | 00-000 0-00 (3) | 4 1111 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T 01 | REPORT SOURCE L (6) | 05000 3 06 (7) | 02 16 79 (8) | 03 16 79 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During surveillance test it was found that instrument 2TM-401B, an overtemperature
03 ΔT Summing Unit, had drifted such that the f (ΔQ) input required to cause trip was
04 12.15% vs. 11%, and the pressurizer pressure input required to cause trip was 2020
05 psig vs. 2040 psig. Redundant channels were operable. No effect on public health
06 and safety. Similar occurrence was RO 79-1.
07
08

09 SYSTEM CODE IA (11) | CAUSE CODE E (12) | CAUSE SUBCODE E (13) | COMPONENT CODE INSTRU (14) | COMP. SUBCODE Y (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 79 | — | SEQUENTIAL REPORT NO. 003 | / | OCCURRENCE CODE 03 | REPORT TYPE L | — | REVISION NO 0

ACTION TAKEN E (18) | FUTURE ACTION X (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS 0000 (22) | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. Y (24) | PRIME COMP. SUPPLIER N (25) | COMPONENT MANUFACTURER F180 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Instrument drift in a Foxboro Model 66RC-0L Summing Unit. Device was immediately
11 recalibrated. Performance of the device is being evaluated frequently to determine
12 if further corrective action is required.
13
14

15 FACILITY STATUS E (28) | % POWER 100 (29) | OTHER STATUS (30) N/A | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) Routine Surveillance Test

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

17 PERSONNEL EXPOSURES: NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA

18 PERSONNEL INJURIES: NUMBER 000 (40) | DESCRIPTION (41) NA

19 LOSS OF OR DAMAGE TO FACILITY: TYPE Z (42) | DESCRIPTION NA (43)

7903200416

20 PUBLICITY: ISSUED N (44) | DESCRIPTION (45) NA

NRC USE ONLY

NAME OF PREPARER A. A. Hunstad PHONE 612-388-4767