Duquesne Light

435 Sixth Avenue
Pittsburgh, Pennsylvania
15219

(412) 471-4300

DUQUESNE LIGHT COMPANY
Beaver Valley Power Station
Post Office Box 4
Shippingport, PA 15077

March 19, 1979
BVPS:JAW:650

Beaver Valley Power Station, Unit No. 1
Docket No. 50-334, License No. DPR-66
LER 79-7/01T

Mr. B. H. Grier, Director of Regulation
United States Nuclear Regulatory Commission
Region 1
631 Park Avenue
King of Prussia, Pennsylvania 19406

Dear Mr. Grier:

In accordance with Appendix A, Beaver Valley Technical Specifications, the following Licensee Event Report is submitted:

LER 79-7/01T, Technical Specifications 6.9.1.8.i and 3.7.1.2, Steam driven auxiliary feedwater pump inoperable and steam generator steam supply check valve inoperable.

Very truly yours,

J. A. Werling
Superintendent

Attachment

7903260273

A002
S/1
S

cc: Director Of Management & Program Analysis ✓
United States Nuclear Regulatory Commission
Washington, D. C. 20555

D. L. Wigginton, BVPS Licensing Project Manager
United States Nuclear Regulatory Commission
Washington, D. C. 20555

D. A. Beckman, Nuclear Regulatory Commission, King of Prussia, PA

G. A. Olson, Secretary, Prime Movers Committee - EEI