TERA

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

February 21, 1979

Docket No. 50-247

Mr. William J. Cahill, Jr.
Vice President
Consolidated Edison Company of
New York, Inc.
4 Irving Place
New York, New York 10003

Dear Mr. Cahill:

RE: INDIAN POINT, UNIT NO. 2

By letter dated September 14, 1977 we informed you of a limited boron dilution incident involving the contents of a spray additive tank at an operating PWR facility. In light of this you were asked to review potential boron dilution incidents at your facility to insure that a similar or other unreviewed method of boron dilution was not more limiting than had been previously analyzed and found acceptable.

Your response of February 23, 1978 indicates that you have reviewed potential boron dilution incidents at your facility and have determined that the FSAR analysis of this event still represents the most limiting case. Based on your response no further action regarding this generic issue is necessary.

Sincerely,

A. Schwencer, Chief
Operating Reactors Branch #1
Division of Operating Reactors

cc: See next page

7903270 203

cc: White Plains Public Library
100 Martine Avenue
White Plains, New York 10601

Joseph D. Block, Esq.
Executive Vice President -
Administration
Consolidated Edison Company
of New York, Inc.
4 Irving Place
New York, New York 10003

Edward J. Sack, Esq.
Law Department
Consolidated Edison Company
of New York, Inc.
4 Irving Place
New York, New York 10003

Anthony Z. Roisman
Natural Resources Defense Council
917 - 15th Street, NW
Washington, D.C. 20005

Paul S. Shemin, Esquire
Assistant Attorney General
State of New York
Department of Law
Two World Trade Center
New York, New York 10047

Sarah Chasis, Esquire
Natural Resources Defense Council
122 East 42nd Street
New York, New York 10017

Theodore A. Rebelwoski
USNRC
P. O. Box 38
Buchanan, New York 10511