



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

PRODUCTION DEPARTMENT

March 15, 1979

Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street - Suite 3100
Atlanta, GA 30303

ATTENTION: Mr. J. P. O'Reilly, Director

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
File 0270/15525/15526
Potential Reportable Deficiency
No. 79/03 - Interim Report No.
1
AECM-79/20

On February 12, 1979, Mississippi Power & Light Company notified Mr. J. K. Rausch of your office of a potential reportable deficiency at the Grand Gulf Nuclear Station construction site. The deficiency concerns General Electric's failure to establish and implement an approved Quality Assurance Program for electrical work performed under Field Deviation Disposition Requests (FDDR) and Field Deviation Instructions (FDI). We will determine reportability of this matter as defined by 10CFR 50.55(e) and make a final report by June 1, 1979.

Yours truly,

for J. P. McGaughy, Jr.
Director of Power Production

JRF/pa

cc: Mr. N. L. Stampley
Mr. R. B. McGehee
Mr. T. B. Conner

Dr. Ernst Volgenau, Director
Division of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

7903270449

*BOA
S/O*