Docket No. 50-329/330

MAR 26 1979

MEMORANDUM FOR: Z. R. Rosztoczy, Chief, Analysis Branch, DSS

FROM: T. M. Novak, Chief, Reactor Systems Branch, DSS

SUBJECT: REVIEW OF TRAP-2 (BAW-10128)

We note in our review of the Midland FSAR that the TRAP-2 code is used to analyze:

1. Steam line break and increase in steam flow transients
2. Feedwater line break and loss of normal feedwater
3. Closure of one main steam isolation valve

BAW-10128 states that TRAP-2 is used for analysis of main steam line breaks and main feedwater line breaks. We request that you confirm that TRAP-2 is appropriate for the events listed above.

Original signed by
G. R. Mazetis for
Thomas M. Novak, Chief
Reactor Systems Branch
Division of Systems Safety

cc: R. Tedesco
M. McCoy
W. Jensen
T. Novak
S. Israel
G. Mazetis
S. Newberry

Distribution:
Docket File (2)
NRR Rdg.
RSB Rdg.
Newberry chron

7904130314

OFFICE	DSS:RSB	DSS:RSB	DSS:RSB			
SURNAME	SNewberry:cj	GMazetis	TNovak			
DATE	03/23/79	03/23/79	03/23/79			

NRC FORM 318 (9-76) NRCM 0240

☆ U. S. GOVERNMENT PRINTING OFFICE: 1976 — 626-624