

# NORTHEAST UTILITIES



THE CONNECTICUT LIGHT AND POWER COMPANY  
THE AMARY OREGON ELECTRIC COMPANY  
THE STATE MICHIGAN ELECTRIC COMPANY  
THE NEW YORK STATE ELECTRIC COMPANY  
THE NEW YORK STATE WATER POWER COMPANY  
THE NEW YORK STATE SERVICE COMPANY  
THE NEW YORK STATE GAS COMPANY

P.O. BOX 270  
HARTFORD, CONNECTICUT 06101  
(203) 666-6911

June 18, 1979

Docket No. 50-336

Director of Nuclear Reactor Regulation  
Attn: Mr. R. Reid, Chief  
Operating Reactors Branch #4  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Reference: (1) V. Stello, Jr., letter to All PWR Licensees dated  
May 25, 1979.

Gentlemen:

Millstone Nuclear Power Station, Unit No. 2  
Feedwater Lines


In Reference (1), the NRC Staff requested, pursuant to 10CFR50.54(f), information regarding the design, fabrication history, and inspection of feedwater lines at Millstone Unit No. 2.

In response to that request, Northeast Nuclear Energy Company (NNECO) hereby provides Attachment 1, Information on Feedwater Lines. As stated in the Attachment, NNECO notes that the feedwater piping system inside containment has been qualified to applicable Code requirements. This, in conjunction with the acceptable operating history, confirms that Millstone Unit No. 2 can continue to operate safely in accordance with the requirements of DPR-65.

This response includes all information available regarding your request; therefore, NNECO has no plans to provide a 60-day supplement to this letter.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

  
\_\_\_\_\_  
W. G. Council  
Vice President

Attachment

25003059

7906216188

ATTACHMENT 1

MILLSTONE NUCLEAR POWER STATION, UNIT NO. 2  
INFORMATION ON FEEDWATER LINES

JUNE, 1979

95003060

## MILLSTONE UNIT NO. 2

## INFORMATION REQUESTED ON PWR FEEDWATER LINES

DESIGN

1. Provide as-built piping or isometric drawings of the feedwater line to steam generator sparger within containment. Show details of the design such as dimensions, pipe schedule, support type and locations, pipe restraints, and valve(s).

RESPONSE

The piping isometric for the Millstone Unit No. 2 feedwater piping system inside containment is provided in enclosed drawing 2503-SKM-326. The design details for the steam generator feedwater nozzle are shown in the enclosed drawing.

95003061

A-16  
 57  
 BY HEILKE  
 BY BIGNY

COMBUSTION ENGINEERING, INC.  
 ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-100-P | A-17  
 SHEET 21 OF 57  
 DATE 12-30-70 BY HEILKE  
 CHECK DATE 12-30-70 BY BIGNY

CHARGE NO. 75267  
 DESCRIPTION BASIS SIZING CALCULATIONS

3.) DETAILED ANALYSIS


d. NOZZLES

3. FEEDWATER

REINFORCEMENT

DESIGN CONDITIONS:  $P = 1000 \text{ PSI}$ ,  $T = 550^\circ \text{ F}$

MATERIALS: SAFE END — SA-508 CLASS 1  $S_m = 18.1 \text{ KSI}$   
 NOZZLE — SA-508 CLASS 2  $S_m = 26.7 \text{ KSI}$   
 SHELL — SA-533 B CLASS 1  $S_m = 26.7 \text{ KSI}$




- $t_{SE} = 0.734 \text{ IN (MIN)}$
- $R_{N2} = 8.063 \text{ IN}$
- $t_{N2} = 0.998 \text{ IN (MIN)}$
- $t_T = 0.998 \text{ IN (MIN)}$
- $R_{N1} = 8.125 \text{ IN}$
- $t_{N1} = 5.609 \text{ IN (MIN)}$
- $R_{S1} = 115.000 \text{ IN}$
- $t_S = 4.813 \text{ IN (MIN)}$
- $r_1 = 4.000 \text{ IN}$
- $r_2 = 4.000 \text{ IN}$
- $R_{SE} = 8.329 \text{ IN}$

CORROSION ALLOWANCE  
 ON INSIDE SURFACE  
 C.A. = 0.0625 IN

95003062

E-233-604

95003043



SEND DRAWING ENG TO CONTRACTOR  
 TO BE MACHINED AFTER WELDING  
 CHECK & BACKING ON THE BACKING  
 TO ASSURE METAL IS WELD

PLAN

ELEVATION

(114.00) FEEDWATER NOZZLE ASSEMBLY  
 SCALE 1 3/4" = 1'-0"

SEE DETAIL 'B' (114.00)

1/2" BRASS STOCK FOR  
 MACHINING AFTER  
 HYDROSTATIC TEST

(114.00) STEAM OUTLET




A.E.D.

11-1-57

PLAN

20.8" DIA

ELEVATION



GENERAL NOTES

1. FOR STANDARD NOTES SEE REF DWG #2 ON APPLICABLE CONTRACT
2. ALL FABRICATION TO BE IN ACCORDANCE WITH ASME CODE SECTION III
3. R# DENOTES DIMENSIONS AS ORDERED FROM MILL
4. ALL WELDS, WHERE TWO OR MORE ARE REQUIRED, HAVING THE SAME NUMBER WILL BE IDENTIFIED WITH SUFFIX A, B, C, ETC., STARTING AT THE 0° AXIS AND GOING CLOCKWISE.

CONTRACT NO.	NO. SHEETS	REF DWG #1	REF DWG #2	REF DN
		DRAWING PLAN	STANDARD AND MATERIAL NOTE	DETAIL PROC
74267	2	B-240-213	B-245-213	A-245
75267	2	B-245-213	B-245-214	A-245

95003064

## MILLSTONE UNIT NO. 2

## INFORMATION REQUESTED ON PWR FEEDWATER LINES

DESIGN


2. Provide the results of any stress or fatigue analyses which was performed for this system.

RESPONSE

The Millstone Unit No. 2 feedwater piping inside containment was designed to ANSI B31.7, Class II-1969. No fatigue analyses are required for Class II piping systems.

A copy of the stress analysis summary for thermal expansion, operating earthquake conditions, design basis earthquake conditions for the feedwater piping system inside containment, and a summary of forces and moments at both steam generator feedwater nozzles for design basis conditions, is enclosed for information.

95003065



CONTAINMENT PENETRATION #15

CONTAINMENT PENETRATION #16

REFERENCE DIMS.

1/4"	3/8"
3/8"	1/2"
1/2"	3/4"
3/4"	1"
1"	1 1/4"
1 1/4"	1 1/2"
1 1/2"	1 3/4"
1 3/4"	2"
2"	2 1/4"
2 1/4"	2 1/2"
2 1/2"	2 3/4"
2 3/4"	3"
3"	3 1/4"
3 1/4"	3 1/2"
3 1/2"	3 3/4"
3 3/4"	4"
4"	4 1/4"
4 1/4"	4 1/2"
4 1/2"	4 3/4"
4 3/4"	5"
5"	5 1/4"
5 1/4"	5 1/2"
5 1/2"	5 3/4"
5 3/4"	6"
6"	6 1/4"
6 1/4"	6 1/2"
6 1/2"	6 3/4"
6 3/4"	7"
7"	7 1/4"
7 1/4"	7 1/2"
7 1/2"	7 3/4"
7 3/4"	8"
8"	8 1/4"
8 1/4"	8 1/2"
8 1/2"	8 3/4"
8 3/4"	9"
9"	9 1/4"
9 1/4"	9 1/2"
9 1/2"	9 3/4"
9 3/4"	10"

FIG. 5-19  
STRESS ANALYSIS MODEL

BECKETT CORPORATION  
STRUCTURAL DIVISION  
100 WEST 42ND STREET  
NEW YORK, N.Y. 10018  
TEL: 212-261-2000

DATE: 12/1/78

BY: J.M. ...

CHKD BY: ...

APP'D BY: ...

SCALE: AS SHOWN

TOP SUPPORT SYSTEM DESIGN ONLY

DETAILS  
SEE SHEET

95003066



**SUMMARY PIPING FLEXIBILITY ANALYSIS**

ANALYST K. KIM DATE 8-26-78

CHECKER F. V. HILADO DATE 8/29/79

APPROVED: [Signature] DATE \_\_\_\_\_

1) TITLE MILLSTONE UNIT 2, MAIN FEEDWATER TO STEAM  
GEN. REP. BUFILE CTMT. ISOMETRIC NO. SK-M-326 Rev 26  
 Thermal Weight Effect Solids

2) PROBLEM NO. 22 DATE OF RUN 8-25-74 8-25-77 8-26-78

3) MATERIAL A516 A-106 GRADE B

4) PIPE SIZE 18" SCH 60

5) OPERATING PRESSURE MAX. 1060 PSI

6) OPERATING TEMPERATURE MAX. 497 °F

7) ANALYSIS:  
12518 NS 4 ASME BOILER & PRESSURE  
K. K. VESSEL CODE SECTION III  
8-26-78 NUCLEAR POWER CONR CLASS

a) Data Point (35) Element Type BEND-E

b) Act'l Expansion Stress 1713 + 14965 = 16650 PSI

c) Allow. Expansion Stress =  $0.125 S_y + 0.25 S_u$  = 22500 PSI

8) OPERATING EARTHQUAKE CONDITION  
 a) Response Spectra Identification EL 50' 0" STEAM CON. UPPER SUPPORT 1% DAMP  
EL 210' CON. STEAM ENCLAVE 1%

b) Data Point (35) Element Type BEND-E

c) Seismic Stress = 2625 PSI

d) Long. Weight Stress = 1061 PSI

e) Long. Press. Stress =  $S_y^2$  = 5576 PSI

f) Total Stress =  $S_c + S_d + S_e$  = 10232 PSI

g) Allow. Seismic Stress =  $1.2 S_y$  = 12000 PSI

9) DESIGN EARTHQUAKE CONDITION

a) Data Point (35) Element Type BEND-E

b) Seismic Stress =  $1.2 S_y$  = 7824 PSI

c) Long. Weight Stress =  $S_d$  = 676 PSI

d) Long. Press. Stress =  $S_e$  = 5576 PSI



e) Total Stress =  $S_b + S_c + S_d$  = 13876 PSI

f) Allow. Max. Seismic Stress =  $S_y$  at Oper. Temp. 22270 PSI @ 497°

g) DUE TO SEISMIC ANCHOR MGMT.

OPERATING WEIGHT

1. STEAM GENERATOR  
 2. STEAM GENERATOR  
 3. STEAM GENERATOR  
 4. STEAM GENERATOR  
 5. STEAM GENERATOR  
 6. STEAM GENERATOR  
 7. STEAM GENERATOR  
 8. STEAM GENERATOR  
 9. STEAM GENERATOR  
 10. STEAM GENERATOR  
 11. STEAM GENERATOR  
 12. STEAM GENERATOR  
 13. STEAM GENERATOR  
 14. STEAM GENERATOR  
 15. STEAM GENERATOR  
 16. STEAM GENERATOR  
 17. STEAM GENERATOR  
 18. STEAM GENERATOR  
 19. STEAM GENERATOR  
 20. STEAM GENERATOR  
 21. STEAM GENERATOR  
 22. STEAM GENERATOR  
 23. STEAM GENERATOR  
 24. STEAM GENERATOR  
 25. STEAM GENERATOR  
 26. STEAM GENERATOR  
 27. STEAM GENERATOR  
 28. STEAM GENERATOR  
 29. STEAM GENERATOR  
 30. STEAM GENERATOR  
 31. STEAM GENERATOR  
 32. STEAM GENERATOR  
 33. STEAM GENERATOR  
 34. STEAM GENERATOR  
 35. STEAM GENERATOR  
 36. STEAM GENERATOR  
 37. STEAM GENERATOR  
 38. STEAM GENERATOR  
 39. STEAM GENERATOR  
 40. STEAM GENERATOR  
 41. STEAM GENERATOR  
 42. STEAM GENERATOR  
 43. STEAM GENERATOR  
 44. STEAM GENERATOR  
 45. STEAM GENERATOR  
 46. STEAM GENERATOR  
 47. STEAM GENERATOR  
 48. STEAM GENERATOR  
 49. STEAM GENERATOR  
 50. STEAM GENERATOR  
 51. STEAM GENERATOR  
 52. STEAM GENERATOR  
 53. STEAM GENERATOR  
 54. STEAM GENERATOR  
 55. STEAM GENERATOR  
 56. STEAM GENERATOR  
 57. STEAM GENERATOR  
 58. STEAM GENERATOR  
 59. STEAM GENERATOR  
 60. STEAM GENERATOR  
 61. STEAM GENERATOR  
 62. STEAM GENERATOR  
 63. STEAM GENERATOR  
 64. STEAM GENERATOR  
 65. STEAM GENERATOR  
 66. STEAM GENERATOR  
 67. STEAM GENERATOR  
 68. STEAM GENERATOR  
 69. STEAM GENERATOR  
 70. STEAM GENERATOR  
 71. STEAM GENERATOR  
 72. STEAM GENERATOR  
 73. STEAM GENERATOR  
 74. STEAM GENERATOR  
 75. STEAM GENERATOR  
 76. STEAM GENERATOR  
 77. STEAM GENERATOR  
 78. STEAM GENERATOR  
 79. STEAM GENERATOR  
 80. STEAM GENERATOR  
 81. STEAM GENERATOR  
 82. STEAM GENERATOR  
 83. STEAM GENERATOR  
 84. STEAM GENERATOR  
 85. STEAM GENERATOR  
 86. STEAM GENERATOR  
 87. STEAM GENERATOR  
 88. STEAM GENERATOR  
 89. STEAM GENERATOR  
 90. STEAM GENERATOR  
 91. STEAM GENERATOR  
 92. STEAM GENERATOR  
 93. STEAM GENERATOR  
 94. STEAM GENERATOR  
 95. STEAM GENERATOR  
 96. STEAM GENERATOR  
 97. STEAM GENERATOR  
 98. STEAM GENERATOR  
 99. STEAM GENERATOR  
 100. STEAM GENERATOR



ITEM	OPERATING WEIGHT		OPERATING BASIS EARTHQUAKE OBE (E) CAL. 88	DESIGN BASIS EARTHQUAKE DBE (E') CAL. 88	SEISMIC MOVEMENT LOAD (DBE) CAL. 88	TOTAL NET DESIGN LOAD
	THERMAL EXPANSION	WEIGHT				
1	- 8738	109	- 1900	4234	1745	16608
2	- 3064	- 3265	- 2880	7965	915	14609
3	- 5602	- 10	- 4660	7938	369	13859
4	26192	16022	24082	65993	13223	109010
5	- 43562	790	616	43304	11076	96212
6	- 6249	1189	- 6172	27163	- 5965	62363

1. ALL WEIGHTS ARE IN POUNDS  
 2. ALL DIMENSIONS ARE IN FEET  
 3. ALL STRENGTHS ARE IN POUNDS PER SQUARE INCH  
 4. ALL MATERIALS ARE AS SPECIFIED IN THE DRAWINGS  
 5. ALL WELDS ARE TO BE MADE IN ACCORDANCE WITH THE REQUIREMENTS OF THE ASME CODE

6. THERMAL LOADS FOR ANCIENT FIRING COND. OP. 1/2 MAX. TEMP AT GEN. MODEL 0 910' F

STEAM PIPING FLEXIBILITY ANALYSIS

1-5

ANALYST K S KIM DATE 4/1/75  
 CHECKER RD KOPPE DATE 4-8-75  
 APPROVED [Signature] DATE 4-1-75

1) TITLE MILLSTONE UNIT 2 FEEDWTR PIPING TO  
STEAM GEN. NO. 1 ISOMETRIC NO. SK-M-326 REV 26

2) PROBLEM NO. 21 DATE OF RUN 3/28/75 3/28/75 3/28/75 3/31/75  
Thermal Weight Effect Service S.M.

3) MATERIAL ASTM A106 GR. B

4) PIPE SIZE 18" SCH. 60

5) OPERATING PRESSURE 1060 PSIG

6) OPERATING TEMPERATURE 437° F

7) ANALYSIS  
03 JCS ASME BOILER AND PRESSURE VESSEL  
4.75 CODE 1971 EDITION, SECTION III  
NUCLEAR POWER PLANT COMPONENTS

8) Data Point (20) Element Type BEND M  
 8a) Actual Expansion Stress 19464 PSI  
 8c) Allow. Expansion Stress =  $61.25 S_y + 0.25 S_u$  = 22500 PSI

9) OPERATING EARTHQUAKE CONDITION

9a) Response Spectrum Identification CONT. INT. EL. 50' / CONT. STRUC. EL. 53'

9b) Data Point (20) Element Type BEND E

9c) Seismic Stress = 10596 PSI

9d) Long. Weight Stress = 1675 PSI

9e) Long. Perm. Stress = 5576 PSI

9f) Total Stress =  $S_r + S_d + S_w$  = 17847 PSI

9g) Allow. Seismic Stress =  $1.2 S_y$  = 18000 PSI

10) DESIGN EARTHQUAKE CONDITION

10a) Data Point (37) Element Type BEND E

10b) Seismic Stress =  $1.5 S_r + S_w$  = 20026 PSI

10c) Long. Weight Stress =  $S_d$  = 1675 PSI

10d) Long. Perm. Stress =  $S_w$  = 5576 PSI

10e) Total Stress =  $S_b + S_c + S_d$  = 27277 PSI

10f) Allow. Max. Seismic Stress =  $S_y$  at Oper. Temp. = 29371 PSI

95003069

K.S. RUP 6 1/2 AD ROMG 4-B-75


PRELIMINARY FILE TO GEN. M. J. JENSEN FROM  
 DIVISION 205

GENERATOR NO. 1

18

SK-M-326, REV. H. 26

21



THERMAL EXPANSION	DEBERTING		Hydraulic	OBE	DDE	SEISMIC MOVEMENT LOAD	TOTAL NET DESIGN LOAD
	WEIGHT FLUID						
-43012	157	-2124	18829	35587	7621	58063	
-7625	-3250	-4619	9977	18753	67	29695	
4926	12	4236	17217	32531	1105	38474	
-33378	-14735	-16255	27168	51348	1817	101278	
73922	-573	41177	52618	99449	39117	211924	
19873	282	-4082	34665	65517	29218	114350	

95003070

REVISIONS: 1. 11/15/54 - 18 - 18  
 2. 11/15/54 - 21 - 21  
 3. 11/15/54 - 21 - 21  
 4. 11/15/54 - 21 - 21

## MILLSTONE UNIT NO. 2

## INFORMATION REQUESTED ON PWR FEEDWATER LINES

FABRICATION HISTORY

1. Supply a list of the materials for the steam generator sparger, steam generator feedwater nozzles, and feedwater piping within containment.

RESPONSE

The list of materials is as follows:

- |   |  |
|---|--|
| 1. Steam Generator Feedwater Nozzle             | SA-508, Class 2  |
| 2. Steam Generator Feedwater Nozzle<br>Safe End | SA-508, Class 1  |
| 3. Steam Generator Sparger                      | ASTM-A-106, Grade B  |
| 4. Feedwater System:                            |  |
| (a) Piping                                      | 18" Schedule 60/<br>ASTM-A-106, Grade B                    |
| (b) Fittings                                    | ASTM A-234, Grade WPB<br>(Wall Thickness to Match<br>Pipe) |

95003071

## MILLSTONE UNIT NO. 2

## INFORMATION REQUESTED ON PWR FEEDWATER LINES


FABRICATION HISTORY

2. Provide the details of the welding process(es) used to make the nozzle-to-pipe, pipe-to-sparger, and piping welds. Include details of welding such as preheat, joint configuration (include with or without backing ring), and post weld treatment, if any.


RESPONSE

- (a) The weld joint configuration for the feedwater piping and pipe-to-safe end welds is as shown on the enclosed drawing 7604-MS-2, Rev. 7, for pipe class EBB 18" Schedule 60 piping.
- (b) The specific welding procedure for the safe end to piping and feedwater piping welds "Welding Procedure Specification PI-AT-Lh (CVN)" is enclosed for information. The root pass of the butt welds was done by the Gas-Tungsten Arc process. The use of consummable inserts was optional. However, if used the consummable inserts were of the same material as the weld filler metal. Permanent backing rings were not used in the subject system welding.
- (c) Preheating of welds was in accordance with Paragraph 1, 2-731-2 of ANSI B31.7.
- (d) Post weld heat treatment for pressure piping welds was in accordance with Paragraph 1, 2-731 of ANSI B31.7.


95003072



**SQUARE BUTT**  
FOR WALL THICKNESS  
3/16 OR LESS



**VEE GROOVE**  
FOR WALL THICKNESS  
OVER 3/16 THRU 3/8



**VEE GROOVE - EXTENDED U/I/D**  
I.D. MACHINED TO 'C' D.I.A.  
FOR WALL THICKNESS OVER 3/8

PIPE CLASS	"A" NOMINAL O. D. OF PIPE	SCHEDULE	(U) NOMINAL WALL THICKNESS	"B" NOMINAL I. D. OF PIPE	"C" MACHINED I. D. +.010 (-0.01)	REMARKS
DBD	16	40	.500	15.000	15.084	
EBD		60	.656	14.688	14.811	
EBD		80	.843	14.314	14.483	
DBD	18	10S	.188	17.624	---	
EBD		40	.562	16.876	16.975	
EBD		60	.750	16.500	16.646	
EBD		80	.937	16.126	16.319	
EBD	24	10S	.250	23.500	---	
DBD		40	.687	22.626	22.756	
EBD		60	.968	22.064	22.320	
EBD		80	1.218	21.564	21.827	
EBD	34	---	0.977 min.	---	32.005	
EBD						
EBD	42	---	.625	40.750	40.865	
EBD						
MBD	16	30	.876	18.260	---	A

\* C.E. SUPPLIED PIPING

NOTE: 1. ALL DIMENSIONS AND TOLERANCES IN DECIMALS  
2. ALL FRACTIONAL DIMENSIONS 1/32" EXCEPT AS NOTED  
3. PIPE USE WITH BRANIFF'S PIPE TO ASTM A-106, A-178, A-312 & WELDED PIPE TO ASTM A-133, A-133A, A-133B



POWER AND INDUSTRIAL DIVISION

FIELD WELD END PREPARATION  
FUNCTION - INERT GAS SHIELDED ARC  
WELDING CONSUMABLE ELECTRODES

HILLSTONE NUCLEAR POWER STATION  
JOB NO. 2

HILLSTONE POINT, CONNECTICUT

JOB NO. 7604  
SPEC. NO. 7604-MS-2

REV

7

95005073

REVISED AND THICKNESS

APPROVALS

FILE NIP2

Welding Standards

PI-AT-Lh (CVN)

Power & Industrial Division

BECHTEL CORPORATION, Welding Procedure Specification

Materials & Fabrication Quality Control Services

By BD Aron  
Manager of Engineering

PI-AT-Lh (CVN) 615  
Revision 0 Date 4/15/71

Prepared DM Duvall  
Approved G. B. Grable  
G. B. Grable

Authorized for use only when signed by the Division Manager of Engineering.

This welding procedure specification must be used in conjunction with the General Welding Standard(s) GWS-FM

Scope: Combination manual gas tungsten-arc and shielded metal-arc welding of impact quality carbon-steel piping materials using the open butt technique without an internal gas purge. This procedure is to be used where impact properties are required.

Base Metal: Carbon steel

Welded to Carbon steel

ASME Sect. IX: P# 1 to P# 1

Welding Process: Gas tungsten-arc (GTA) and shielded metal-arc (SMA)

Filler Material SFA-5.18/SA5.18, Classification E70S-2 and SFA-5.1/AWS A5.1, Classification E7018 (Note 2)

ASME Sect. IX: F# 4 & 6 A# 1

Position(s) Qualified: All positions


Thickness Range Qualified: (Note 3)  
As-welded: Min. 3/16" Max. 2-1/4"  
Postweld Heat Treated: Min. 3/16" Max. 2-1/4"

Backing Material None

Min. Preheat Temp. 60°F (Note 4)

Interpass temperature 350°F max.

Postweld Heat Treat: (When required) one hour/ inch at 1100°F-1200°F (refer to PHT-500 & PHT-501)



Applicable Procedure Qualification Record(s): PQR-19 & PQR-20

Procedure Qualified to: ASME Section IX and ASME Section III, Para. N-541

Welding Process	GTA	GTA	SMA	SMA	SMA
Layer Number	1	2	3 & Rem.	Remainder	Remainder
Travel Speed (in. /min)	1-6	1-6	2-11	2-11	2-11
Amperage Range	60-100	60-100	70-100	115-165	140-180
AC/DC, Polarity	DCSP	DCSP	DCRP	DCRP	DCRP
Voltage	10-16	10-16	22-28	22-28	22-28
Torch Gas - cfh.	Argon 18-25	Argon 18-25	---	---	---
Backing Gas - cfh.	None	None	---	---	---
Electrode Diameter	3/32" or 1/8"	3/32" or 1/8"	3/32"	1/8"	5/32"
Tungsten Type	1%-2% Thor.	1%-2% Thor.	---	---	---
Filler Wire Diameter	1/8"	3/32" or 1/8"	---	---	---

Additional Instructions

- Note 1: File the top corner at about 45° to produce approximately a 1/32-inch land thickness.
- Note 2: AWS A5.18 may be used when identical to ASME SFA-5.18. AWS A5.1 may be used when identical to ASME SFA-5.1.
- Note 3: See PHT-500 for maximum allowable as-welded thickness permitted under the particular Code governing the fabrication.

95003074



Welding Procedure Specification

PI-AT-Lh (CVN)

Revision 0 Date 4/15/71

Additional Instructions (Continued from Page 1)

Note 4: See Drawing GWS-FM-1 for special circumstances where higher pre-heat temperatures are required.

95003075

## MILLSTONE UNIT NO. 2

## INFORMATION REQUESTED ON PWR FEEDWATER LINES

FABRICATION HISTORY

3. Provide the NDE performed during and after fabrication of the weld joints requested in Question 2.

RESPONSE

For shop fabricated feedwater pipe, the NDE during and after fabrication of the weld joints was basically in conformance with the procedural and quality requirements set forth in the applicable section of B31.7 (1969) and Section IX of the ASME Code.

For field fabricated and installed feedwater pipe inside containment, the NDE during and after fabrication of the weld joints was performed in accordance with the requirements of ASME III (1971 Edition), Class II.

In addition to the above requirements, the following NDE was performed:

- (a) Each layer of welding was inspected for smoothness, slag inclusion, cracks, pin holes, undercut, and fusion to adjacent weld beads and base metal.
- (b) All butt welds in the feedwater piping system inside containment were 100% radiographed in accordance with the applicable code.

95003076

## MILLSTONE UNIT NO. 2

## INFORMATION REQUESTED ON PWR FEEDWATER LINES

FABRICATION HISTORY

4. Provide the Code edition to which the feedwater piping system was fabricated.

RESPONSE

The shop fabrication of the feedwater system piping inside containment was done in accordance with the code for nuclear power piping ANSI B31.7-1969. The field fabrication and installation of the feedwater piping inside containment was done in accordance with ASME III (1971 edition), Class II.

95003077

## MILLSTONE UNIT NO. 2

## INFORMATION REQUESTED ON PWR FEEDWATER LINES

FABRICATION HISTORY

5. State the fracture toughness requirements, if any, for the feedwater piping system.

RESPONSE

A Charpy V-notch NDTT temperature of +20°F was specified for the 18" Schedule 60 pipe class EBB (feedwater piping inside containment) piping. The minimum absorbed energy was in accordance with N-421 of the ASME III Code.

95003078

## MILLSTONE UNIT NO. 2

## INFORMATION REQUESTED ON PWR FEEDWATER LINES

PRESERVICE/INSERVICE INSPECTION AND OPERATING HISTORY

1. State whether the feedwater system welds received a preservice inspection in accordance with ASME Boiler & Pressure Vessel Code, Section XI.

RESPONSE

A preservice examination of the two (2') steam generator feedwater nozzle to shell welds was conducted for information only in January 1975. These examinations were performed to the criteria of ASME Section XI, Winter, 1972 Addendum. No reportable indications were noted.

The balance of the feedwater system did not receive a preservice inspection as requirements to invoke the Summer 1975 Addendum to ASME XI did not become effective at Millstone Unit No. 2 until April 26, 1979.

95003079

## MILLSTONE UNIT NO. 2

## INFORMATION REQUESTED ON PWR FEEDWATER LINES

PRESERVICE/INSERVICE INSPECTION AND OPERATING HISTORY

2. Provide the extent of inservice inspection performed on the feedwater pipe to steam generator nozzle welds. Include the results of the examinations, any corrective actions taken, and causes of any failures.

RESPONSE

There have been no inservice inspections of the Class 2 portions of the feedwater system to date.

95003080

## MILLSTONE UNIT NO. 2

## INFORMATION REQUESTED ON PWR FEEDWATER LINES

PRESERVICE/INSERVICE INSPECTION AND OPERATING HISTORY

3. Provide the schedule and extent of inservice inspection for the feedwater system for the next inspection interval.

RESPONSE

Present plans call for volumetric examination of one 18" feedwater piping to steam generator nozzle weld before July 1982 and two 18" piping welds before the end of the present (first) inspection interval in December 1985, per Category C-G, Summer 1975 Addenda.

95003081

## MILLSTONE UNIT NO. 2

## INFORMATION REQUESTED ON PWR FEEDWATER LINES

PRESERVICE/INSERVICE INSPECTION AND OPERATING HISTORY

4. Provide any history of water hammer or vibration in the feed-water system and design changes and/or actions taken to prevent these occurrences.

RESPONSE

During the performance of T-INT-3000, Precore Hot Functional Test, a water hammer was observed coincident with a cooldown transient resulting from a pressurizer relief valve that lifted. This has been the only observed water hammer. The engineering solution consisted of installing standpipes in the feed ring of both steam generators. This fix was implemented between precore and postcore hot functionals and was satisfactorily tested during the Postcore Hot Functional Test. A further refinement of the modifications was made during December 1976 and January 1977. This consisted of removing all of the standpipes and blanking the holes. Thirty-six (36) three and one-half inch (3½") elbows were installed around the top of the feed rings. This modification was tested with feed rates up to 600 gpm after the feed ring had been uncovered for fifteen (15) minutes with no observed water hammer. These are the present restrictions as specified in Amendment No. 32 of our operating license.

95003082



## MILLSTONE UNIT NO. 2

## INFORMATION REQUESTED ON PWR FEEDWATER LINES

PRESERVICE/INSERVICE INSPECTION AND OPERATING HISTORY

5. Provide a description of feedwater chemistry controls and a summary of chemistry data.

RESPONSE

Feedwater chemistry controls for Millstone Unit No. 2 are summarized in Table 1. When the normal value is exceeded, the cause of the problem is investigated and corrected. Plant responses to exceeding a normal chemistry escalate, depend on the parameter and nature of the problem. Control values in chemistry conditions that require various actions including power reduction and shutdown are listed in Table 1.

Some chemistry parameters are monitored continuously by means of on-line analyzers, as indicated in Table 1. The other listed parameters are determined on a sampling basis.

Feedwater chemistry is also controlled indirectly by means of steam generator chemistry control. Thus, with some parameters, a fault feedwater condition would be detected in the steam generator prior to becoming detectable in the feedwater, due to the concentrating action that occurs in steam generators. On-line analyzers and chemistry controls for steam generator chemistry are provided in Table 1.

Typical chemistry data for Millstone Unit No. 2 is given in Table 2.

95003083

MILLSTONE UNIT NO. 2

INFORMATION REQUESTED ON PWR FEEDWATER LINES

TABLE 1  
CHEMISTRY CONTROLS AT MILLSTONE UNIT NO. 2

SYSTEM	PARAMETERS	ON-LINE ANALYZERS	NORMAL <sup>1</sup>	CONTROL VALUE	
				A <sup>2</sup>	B <sup>3</sup>
Feedwater	SiO <sub>2</sub> ppb		<10		
	pH	Yes	8.8-9.2		
	Cat. Cond. umhos/cm	Yes	<.5		10
	O <sub>2</sub> ppb	Yes	<10		
	N <sub>2</sub> H <sub>4</sub> ppb	Yes	10-50		
	NH <sub>3</sub> ppm		<1		
	Cu, ppb		<10		10
	Fe, ppb		<10		30
	Cl, ppm		<.05		
Steam Generator	pH	Yes	8.2-9.2		7.5-9.5
	Cond. umhos/cm	Yes	<7	7	15
	Sus.Sol., ppm		<1		10
	OH, ppm		0		5
	SiO <sub>2</sub> ppm		<1		10
	Cl, ppm		<0.1		0.1
	Cat. Cond. umhos/cm	Yes	<2	2	
	Na, ppin	Yes	<0.1	0.1	

1. When these values are exceeded, the cause of the problem is investigated and corrected.
2. Actions based on exceeding these values are: chloride sampling, blowdown increase, condenser leak isolation/repair, etc.
3. Shutdown or power-reduction requirement is based on exceeding these values.

95003084

## MILLSTONE UNIT NO. 2

## INFORMATION REQUESTED ON PWR FEEDWATER LINES

TABLE 2  
 TYPICAL CHEMISTRY DATA AT MILLSTONE UNIT NO. 2  
 (DATA FROM WEEK ENDING 1/06/79)

SYSTEM	PARAMETER	VALUE
Feedwater	pH	8.95
	Cat. Cond. $\mu\text{mhos/cm}$	0.05
	Oxygen, ppb	3.0
	Hydrazine, ppb	8
	Ammonia, ppb	201
	Copper, ppb	6.1
	Iron, ppb	2.7
Steam Generator	pH	8.71
	Cat. Cond. $\mu\text{mhos/cm}$	0.6
	Cond. $\mu\text{mhos/cm}$	1.70
	Sus. Sol., ppm	<0.010
	Chloride, ppm	<0.05
	Sodium, ppb	9.4
	Ammonia, ppm	0.144
	Copper, ppb	0.35
	Iron, ppb	2.6
Silica, ppm	<1.0	

95003085