



Wisconsin Electric POWER COMPANY
231 W. MICHIGAN, P.O. BOX 2046, MILWAUKEE, WI 53201

November 27, 1979

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. NUCLEAR REGULATORY COMMISSION
Washington, D. C. 20555

Attention: Mr. A. Schwencer, Chief
Operating Reactor Branch No. 1

Gentlemen:

DOCKET NOS. 50-266 AND 50-301
LOW PRESSURE ECCS EVALUATION FOR
18% STEAM GENERATOR TUBE PLUGGING
POINT BEACH NUCLEAR PLANT UNITS 1 AND 2

Enclosed herewith are the results of an ECCS reanalysis for operation of the Point Beach Nuclear Plant Units 1 and 2 at a reduced primary system pressure of 2000 psia with up to 18% of the U-tubes plugged in each steam generator. On the basis of generic sensitivity studies, which showed that the limiting break for Westinghouse two-loop plants with 14x14 fuel is a double-ended, cold-leg, guillotine pipe break with a discharge coefficient of 0.4, only the analysis for this specific limiting break for the Point Beach Nuclear Plant is provided. The results of these generic sensitivity studies were provided to you previously with our letter dated March 20, 1979.

The enclosed reanalysis was conducted at a reduced primary system pressure of 2000 psia using a core inlet temperature of a nominal 544°F. As the Point Beach Nuclear Plant utilizes upper plenum injection, a 60°F increase in temperature should be added to the calculated peak clad temperature to account for explicit modeling of upper plenum injection. Westinghouse has determined for the Point Beach Nuclear Plant that fuel rod bursting and blockage is appropriately accounted for in the ECCS analysis results. These results demonstrate that the Emergency Core Cooling System continued to meet the Acceptance Criteria as presented in 10 CFR Part 50.46 of the Commission's Regulations.

As you know, an ECCS reanalysis for the 18% steam generator tube plugging limit and operation at 2250 psia was submitted to you by letter dated November 19, 1979. At that time, we stated that Westinghouse ECCS sensitivity studies have shown that operation at reduced pressure of 2000 psia will have an insignificant effect on the analysis results. The attached reanalysis confirms this statement.

A001
S
1/1

Mr. Harold R. Denton, Director

-2-

November 27, 1979

Should you have any questions regarding this analysis, please notify us as soon as possible so that we may provide you any necessary clarifications.

Very truly yours,

C. W. Fay, Director
Nuclear Power Department

The Loss of Coolant Accident (LOCA) has been reanalyzed for Point Beach Units 1 and 2. The following information amends the Safety Analysis Report section on Major Reactor Coolant System Pipe Ruptures. The results are consistent with acceptance criteria provided in reference (1).

The description of the various aspects of the LOCA analysis is given in WCAP-8239.^[2] The individual computer codes which comprise the Westinghouse Emergency Core Cooling System (ECCS) evaluation model are described in detail in separate reports^[3-6] along with code modifications specified in references 7, 9 and 10. The analysis presented here was performed with the February 1978 version of the evaluation model which includes modifications delineated in references 11, 12, 13 and 14.

Results

The analysis of the loss of coolant accident is performed at 102 percent of the licensed core power rating. The peak linear power and total core power used in the analysis are given in Table 2. Since there is margin between the value of peak linear power density used in this analysis and the value of the peak linear power density expected during plant operation, the peak clad temperature calculated in this analysis is greater than the maximum clad temperature expected to exist.

Table 1 presents the occurrence time for various events throughout the accident transient.

Table 2 presents selected input values and results from the hot fuel rod thermal transient calculation. For these results, the hot spot is defined as the location of maximum peak clad temperatures. That location is specified in Table 2 for each break analyzed. The location is indicated in feet which presents elevation above the bottom of the active fuel stack.

Table 3 presents a summary of the various containment systems parameters and structural parameters which were used as input to the COCO computer code^[6] used in this analysis.

Tables 4 and 5 present reflood mass and energy releases to the containment, and the broken loop accumulator mass and energy release to the containment, respectively.

The results of several sensitivity studies are reported.^[8] These results are for conditions which are not limiting in nature and hence are reported on a generic basis.

Figures 1 through 17 present the transients for the principal parameters for the break sizes analyzed. The following items are not shown:

Figures 1 - 3: Quality, mass velocity and clad heat transfer coefficient for the hotspot and burst locations

Figures 4 - 6: Core pressure, break flow, and core pressure drop.
The break flow is the sum of the flowrates from both

ends of the guillotine break. The core pressure drop is taken as the pressure just before the core inlet to the pressure just beyond the core outlet

Figures 7 - 9: Clad temperature, fluid temperature and core flow. The clad and fluid temperatures are for the hot spot and burst locations

Figures 10 - 11: Downcomer and core water level during reflood, and flooding rate

Figures 12 - 13: Emergency core cooling system flowrates, for both accumulator and pumped safety injection

Figures 14 - 15: Containment pressure and core power transients

Figures 16 - 17: Break energy release during blowdown and the containment wall condensing heat transfer coefficient for the worst break

Conclusions & Thermal Analysis

For breaks up to and including the double ended severance of a reactor coolant pipe, the Emergency Core Cooling System will meet the Acceptance Criteria as presented in 10CFR50.46.[1]. That is:

1. The calculated peak clad temperature does not exceed 2200°F based on a total core peaking factor of 2.32.
2. The amount of fuel element cladding that reacts chemically with water or steam does not exceed 1 percent of the total amount of Zircalloy in the reactor.
3. The clad temperature transient is terminated at a time when the core geometry is still amenable to cooling. The cladding oxidation limits of 17 percent are not exceeded during or after quenching.
4. The core temperature is reduced and decay heat is removed for an extended period of time, as required by the long-lived radioactivity remaining in the core.

The effects of upper plenum injection for Westinghouse-designed 2-loop plants has been discussed with the staff.[15,16,17,18,19] Based on interim calculations, a 60°F increase in calculated peak clad temperatures results from explicit modelling of upper plenum injection in the Point Beach power plant. In order to use the present Westinghouse ECCS evaluation model[13,14,15] to analyze a postulated LOCA in the

Point Beach plants and remain in compliance with 10CFR50.46, a limit of 2140°F on calculated peak clad temperatures must be observed. It can be seen from the results contained herein that this ECCS analysis for the Point Beach power plants remains in compliance with 10CFR50.46.

References for Section 15.4.1

1. "Acceptance Criteria for Emergency Core Cooling Systems for Light Water Cooled Nuclear Power Reactors," 10CFR50.46 and Appendix K of 10CFR50.46. Federal Register, Volume 39, Number 3, January 4, 1974.
2. Bordelon, F. M., Messie, H. W., and Zordan, T. A., "Westinghouse ECCS Evaluation Model-Summary," WCAP-8339, July 1974.
3. Bordelon, F. M., et al., "SATAN-VI Program: Comprehensive Space-Time Dependent Analysis of Loss-of-Coolant," WCAP-8302 (Proprietary Version), June 1974.
4. Bordelon, F. M., et al., "LOCTA-IV Program: Loss-of-Coolant Transient Analysis," WCAP-8301 (Proprietary Version), WCAP-8305 (Non-Proprietary Version), June 1974.
5. Kelly, R. D., et al., "Calculational Model for Core Reflooding After a Loss-of-Coolant Accident (WREFLOOD Code)," WCAP-8170 (Proprietary Version), WCAP-8171 (Non-Proprietary Version), June 1974.
6. Bordelon, F. M., and Murphy, E. T., "Containment Pressure Analysis Code (COCO)," WCAP-8327 (Proprietary Version), WCAP-8326 (Non-Proprietary Version), June 1974.
7. Bordelon, F. M., et al., "The Westinghouse ECCS Evaluation Model: Supplementary Information," WCAP-8471 (Proprietary Version), WCAP-8472 (Non-Proprietary Version), January 1975.

8. Salvatori, R., "Westinghouse ECCS - Plant Sensitivity Studies," WCAP-8340 (Proprietary Version), WCAP-8356 (Non-Proprietary Version), July 1974.
9. "Westinghouse ECCS Evaluation Model, October, 1975 Versions," WCAP-8622 (Proprietary Version), WCAP-8623 (Non-Proprietary Version), November, 1975.
10. Letter from C. Eicheldinger of Westinghouse Electric Corporation to D. B. Vassallo of the Nuclear Regulatory Commission, letter number NS-CE-924, January 23, 1976.
11. Kelly, R. D., Thompson, C. M., et. al., "Westinghouse Emergency Core Cooling System Evaluation Model for Analyzing Large LOCA's During Operation With One Loop Out of Service for Plants Without Loop Isolation Valves," WCAP-9166, February, 1978.
12. Eicheldinger, C., "Westinghouse ECCS Evaluation Model, February 1978 Version," WCAP-9220-P-A (Proprietary Version), WCAP-9221-A (Non-Proprietary Version), February, 1978.
13. Letter from T. M. Anderson of Westinghouse Electric Corporation to John Stolz of the Nuclear Regulatory Commission, letter number NS-TMA-1981, Nov. 1, 1978.
14. Letter from T. M. Anderson of Westinghouse Electric Corporation to R. L. Tedesco of the Nuclear Regulatory Commission, letter number NS-TMA-2014, December 11, 1978.

15. "Safety Evaluation Report on ECCS Evaluation Model for Westinghouse Two-Loop Plants," November, 1977.
- 16.* Letter from V. J. Esposito to H. W. Gutzman of NSD Operations Support, both from Westinghouse Electric Corporation, letter number SE-SAI-2267, January 30, 1978.
17. "NRC Questions Regarding TAC 1/16/78 Submittal by Westinghouse Designed Two-Loop Plant Operators," February 1, 1978..
- 18.* Letter from V. J. Esposito to H. W. Gutzman of NSD Operations Support, both from Westinghouse Electric Corporation, letter number SE-SAI-2290, February 17, 1978.
19. "Safety Evaluation Report on Interim ECCS Evaluation Model for Westinghouse Two-Loop Plants," March 1978.

*Wisconsin Electric Power should supply the proper references by which these references were formally transmitted to the NRC.

TABLE 1

LARGE BREAK - TIME SEQUENCE OF EVENTS

Event	Occurrence Time (Seconds)	
	DECLG, $C_D = 0.4$	
Accident Initiation	0.0	
Reactor Trip Signal	1.5 .37	
Safety Injection Signal	.8	
Start Accumulator Injection	1.1 9.2	
End of ECC Bypass	22.0 21.7	
End of Blowdown	22.0 21.7	
Bottom of Core Recovery	42.6 42.1	
Accumulators Empty	57.3 57.2	
Start Pumped ECC Injection	25.8	

TABLE 2

LARGE BREAK - ANALYSIS INPUT AND RESULTSQuantities in the Calculations:

Licensed core power rating	102 percent of 1518.5 MWt
Total core peaking factor	2.32
Peak linear power	102 percent of 13.23 kw/ft
Accumulator water volume	1100 cubic feet per tank
Accumulator pressure	700 psia
Number of safety injection pumps operating	2
Steam generator tube plugging level	18 percent (uniform)
Fuel parameters -	Cycle: <u>Generic</u> Region: <u>Generic</u>

ResultsDECLG, C_D = 0.4

Peak clad temperature (°F)	2053 2062
Location (feet)	7.5
Maximum local clad/water reaction (percent)	5711 4.3
Location (feet)	7.5
Total core clad/water reaction (percent)	<0.3
Hot rod burst time (seconds)	21.2 29.6
Location (feet)	5.75

TABLE 3

CONTAINMENT DATA (DRY CONTAINMENT)

Net Free Volume	$1.065 \times 10^6 \text{ ft}^3$
Initial Conditions	
Pressure	14.7 psia
Temperature	90 °F
RWST Temperature	34 °F
Service Water Temperature	33 °F
Outside Temperature	-25 °F
Spray System	
Number of Pumps Operating	2
Runout Flow Rate	1950 gpm each
Actuation Time	10 secs
Safeguards Fan Coolers	
Number of Fan Coolers Operating	4
Fastest Post Accident Initiation of Fan Coolers	35 secs

TABLE 3 (Cont)

STRUCTURAL HEAT SINK DATA *

<u>Thickness (in)</u>	<u>Material</u>	<u>Area, ft²</u>
.322	Steel/concrete, 12	56020
.188	Steel/concrete, 12	6230
.25	Steel/concrete, 12	2480
.188	Steel/concrete, 12	690
.094	Steel	103724
.304	Steel	11710
.443	Steel	4730
.584	Steel	5441
.712	Steel	4490
1.0	Steel	957
2.634	Steel	3667
.125	Steel	10221
.209	Steel	16551
.5	Steel	2707
.322	Steel	13835
.055	Steel	141106
.036	Steel	38250
.1	Steel/concrete, 3	19500
3.0	Concrete	19500
30.0	Concrete	61500

TABLE 3 (Cont)

PAINTED STRUCTURAL HEAT SINK DATA

<u>Structural Heat Sink Surface Area (Ft²)</u>	<u>Structural Heat Sink Thickness (In)</u>	<u>Paint Thickness (Mils)</u>
56020	.322	7.5
2400	.25	7.5
103724	.094	7.5
11710	.304	7.5
4730	.443	7.5
5441	.504	7.5
4490	.712	7.5
957	1.0	7.5
3057	2.634	6.0
10221	.125	6.0
16551	.209	6.0
2707	.5	6.0

TABLE 4

REFLOOD MASS AND ENERGY RELEASE

<u>Time (Sec)</u>	<u>Mass Flow (Lb/Sec)</u>	<u>Energy Flow (Lb/Sec)</u>
42.7	.013	16.7
44.3	.42	543.7
48.9	27.3	26722.
59.8	47.4	64157.
73.4	54.5	66427.
87.6	173.2	96367.
107.8	211.73	96704.
127.2	216.2	94049.
173.2	222.7	87277.
222.2	221.2	77927.

TABLE 5

POOR ORIGINAL

BROKEN LOOP ACCUMULATOR MASS AND ENERGY RELEASE

TIME (SEC)	MASS FLOW ($\frac{lb}{sec}$)	ENERGY FLOW ($\frac{BTU}{sec}$)
1.010	2523.301	151120.523
2.010	2412.643	146493.209
3.010	2317.511	138795.761
4.010	2234.541	131226.681
5.010	2160.090	123855.087
6.010	2092.169	125299.939
7.010	2029.721	121560.017
8.010	1972.231	116116.917
9.010	1919.719	116971.994
10.010	1871.489	112093.454
11.010	1827.145	109427.719
12.010	1786.237	106977.723
13.010	1748.010	104693.128
14.010	1712.747	102576.466
15.010	1680.074	100519.639
16.010	1649.766	98604.472
17.010	1621.515	97112.515
18.010	1595.055	95820.454
19.010	1570.170	94637.401
20.010	1546.639	93580.129
21.010	1524.340	91455.731
21.592	1507.994	90313.772
21.903	1507.577	90263.712
21.909	1507.556	90287.533
22.009	1503.052	90155.692
22.122	1503.015	90015.546
22.122	1503.015	90015.546
22.202	1499.028	89824.736
22.402	1495.650	89576.601
22.602	1491.537	89301.167
22.802	1487.514	89007.241
23.002	1483.475	88695.300
23.202	1479.436	88365.100
23.402	1475.402	88017.013
23.602	1471.360	87651.029
23.802	1467.344	87267.209
24.002	1463.347	86863.614
24.202	1459.356	86443.156
24.402	1455.361	86004.710
24.602	1451.371	85545.290
25.002	1444.460	84509.165
25.202	1438.570	83916.419
26.002	1424.061	81355.233
26.502	1410.540	80765.210
27.002	1403.011	80205.995
27.502	1395.648	79657.215
28.002	1387.053	79116.922
28.502	1379.022	78592.627
29.002	1370.369	78070.169
29.502	1361.119	77559.980
30.002	1353.497	77050.545
30.502	1345.220	76555.765
31.002	1337.161	76061.135
31.502	1329.100	75565.097
32.002	1321.367	75065.662
32.502	1313.674	74575.913
33.002	1305.404	74082.512
33.502	1297.655	73586.413
34.002	1291.223	73087.369
34.502	1284.100	72585.008
35.002	1276.956	72079.405
35.502	1269.992	71570.213
36.002	1263.101	71057.505
36.502	1256.303	70540.591
37.002	1249.519	70019.670
37.502	1242.740	69494.744
38.002	1235.966	68965.812
38.502	1229.197	68432.874
39.002	1222.433	67895.932
39.502	1215.674	67354.987
40.002	1208.920	66809.040
40.502	1202.171	66263.092
41.002	1195.427	65717.143
41.502	1188.688	65171.194
42.002	1181.954	64625.245
42.502	1175.225	64079.296
43.002	1168.501	63533.347
43.502	1161.782	62987.398
44.002	1155.068	62441.449
44.502	1148.359	61895.500
45.002	1141.655	61349.551
45.502	1134.956	60803.602
46.002	1128.262	60257.653
46.502	1121.573	59711.704
47.002	1114.889	59165.755
47.502	1108.200	58619.806
48.002	1101.516	58073.857
48.502	1094.837	57527.908
49.002	1088.163	56981.959
49.502	1081.494	56435.990
50.002	1074.830	55889.991
50.502	1068.171	55343.992
51.002	1061.517	54797.993
51.502	1054.868	54251.994
52.002	1048.224	53705.995
52.502	1041.585	53159.996
53.002	1034.951	52613.997
53.502	1028.322	52067.998
54.002	1021.698	51521.999
54.502	1015.079	50975.999
55.002	1008.465	50429.999
55.502	1001.856	49883.999
56.002	995.252	49337.999
56.502	988.653	48791.999
57.002	982.059	48245.999
57.502	975.470	47699.999
58.002	968.886	47153.999
58.502	962.307	46607.999
59.002	955.733	46061.999
59.502	949.164	45515.999
60.002	942.600	44969.999
60.502	936.041	44423.999
61.002	929.487	43877.999
61.502	922.938	43331.999
62.002	916.394	42785.999
62.502	909.855	42239.999
63.002	903.321	41693.999
63.502	896.792	41147.999
64.002	890.268	40601.999
64.502	883.749	40055.999
65.002	877.235	39509.999
65.502	870.726	38963.999
66.002	864.222	38417.999
66.502	857.723	37871.999
67.002	851.229	37325.999
67.502	844.740	36779.999
68.002	838.256	36233.999
68.502	831.777	35687.999
69.002	825.303	35141.999
69.502	818.834	34595.999
70.002	812.370	34049.999
70.502	805.911	33503.999
71.002	799.457	32957.999
71.502	793.008	32411.999
72.002	786.564	31865.999
72.502	780.125	31319.999
73.002	773.691	30773.999
73.502	767.262	30227.999
74.002	760.838	29681.999
74.502	754.419	29135.999
75.002	747.995	28589.999
75.502	741.576	28043.999
76.002	735.162	27497.999
76.502	728.753	26951.999
77.002	722.349	26405.999
77.502	715.950	25859.999
78.002	709.556	25313.999
78.502	703.167	24767.999
79.002	696.783	24221.999
79.502	690.404	23675.999
80.002	684.030	23129.999
80.502	677.661	22583.999
81.002	671.297	22037.999
81.502	664.938	21491.999
82.002	658.584	20945.999
82.502	652.235	20399.999
83.002	645.891	19853.999
83.502	639.552	19307.999
84.002	633.218	18761.999
84.502	626.889	18215.999
85.002	620.565	17669.999
85.502	614.246	17123.999
86.002	607.932	16577.999
86.502	601.623	16031.999
87.002	595.319	15485.999
87.502	589.020	14939.999
88.002	582.726	14393.999
88.502	576.437	13847.999
89.002	570.153	13301.999
89.502	563.874	12755.999
90.002	557.599	12209.999
90.502	551.329	11663.999
91.002	545.064	11117.999
91.502	538.804	10571.999
92.002	532.549	10025.999
92.502	526.299	9479.999
93.002	520.054	8933.999
93.502	513.814	8387.999
94.002	507.579	7841.999
94.502	501.349	7295.999
95.002	495.124	6749.999
95.502	488.904	6203.999
96.002	482.689	5657.999
96.502	476.479	5111.999
97.002	470.274	4565.999
97.502	464.074	4019.999
98.002	457.879	3473.999
98.502	451.689	2927.999
99.002	445.504	2381.999
99.502	439.324	1835.999
100.002	433.149	1289.999

POOR ORIGINAL




Figure 1




Figure 2

POOR ORIGINAL




Figure 3

POOR ORIGINAL




Figure 4




Figure 5

1000

2000

3000

4000


5000

6000

7000

COIL PRESSURE (PSI)

POINT BEACH NUCLEAR PLANT 10 PERCENT TUBE PLUGGING 2030 PSIA
COIL PRESSURE (PSI) COLD LEG CIRCULATING -- CO = 0.4
CASE P2.0000



25.000

20.000

15.000

10.000

5.0000

TIME (SEC)

Figure 5




Figure 7




Figure 8




Figure 9




Figure 10





Figure 12

POOR ORIGINAL



129

+

20

2

५००

(C)

Uffiz

Cyber

Time (sec)

Figure 13

Plant Production Plant
100% Pure 100% Pure 2000 PSI
DEC 10 Cb = 0.4

POOR ORIGINAL




Figure 14




Figure 15




Figure 16

POOR ORIGINAL

Point Beach Nuclear Plant
15% Plug Flow 100% Power 2000 PSI
DECIDE $C_D = 0.1$

Figure 17

