



# Duquesne Light

435 Sixth Avenue  
Pittsburgh, Pennsylvania  
15219

(412) 471-4300

DUQUESNE LIGHT COMPANY  
Beaver Valley Power Station  
Post Office Box 4  
Shippingport, PA 15077

January 26, 1979  
BVFS:JAW:629

Beaver Valley Power Station, Unit No. 1  
Docket No. 50-334, License No. DPR-66  
LER 78-65/03L


Mr. B. H. Grier, Director of Regulation  
United States Nuclear Regulatory Commission  
Region 1  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

Dear Mr. Grier:

In accordance with Appendix A, Beaver Valley Technical Specifications,  
the following Licensee Event Report is submitted:

LER 78-65/03L, Technical Specification 4.7.7.1.d.3, Inability of control  
room emergency habitability system to maintain control room at  $\geq 1/8$  inch above  
the outside atmosphere.

Very truly yours,

  
J. A. Werling  
Superintendent

Attachment

79013100 46

A002  
5/11  
5

Mr. B. H. Grier  
January 26, 1979  
BVPS:JAW:629  
Page 2

cc: Director Of Management & Program Analysis ✓  
United States Nuclear Regulatory Commission  
Washington, D. C. 20555

D. L. Wigginton, BVPS Licensing Project Manager  
United States Nuclear Regulatory Commission  
Washington, D. C. 20555

D. A. Beckman, Nuclear Regulatory Commission, King of Prussia, PA

G. A. Olson, Secretary, Prime Movers Committee - EEI