

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: _____ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | A | R | A | N | O | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | - | 0 | 0 | 4 | 1 | 1 | 1 | 1 | _____ (5)
7 8 9 14 15 25 26 57 58

CON'T

0 1 | R | E | P | O | R | T | S | O | U | R | C | E | L | 0 | 5 | 0 | 0 | 0 | 3 | 6 | 8 | 7 | 1 | 2 | 2 | 8 | 7 | 8 | 0 | 1 | 2 | 5 | 7 | 9 | _____ (9)
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During Mode 2 operation, 2P7A, Emergency Feedwater Pump A, tripped on _____
0 3 | overspeed when started for feeding steam generators violating _____
0 4 | T.S.3.7.1.2. Redundant Emergency Feedwater pump was available. No _____
0 5 | similar occurrences. Reportable per T.S.6.9.1.9(b). _____
0 6 | _____
0 7 | _____
0 8 | _____

0 9 | W | B | 11 | E | 12 | A | 13 | I | N | S | T | R | U | 14 | C | 15 | Z | 16 | _____
7 8 9 10 11 12 13 18 19 20

17 | L | E | R | / | H | O | R | E | R | E | P | O | R | T | N | U | M | B | E | R | 7 | 8 | _____ (21) 22 | S | E | Q | U | E | N | T | I | A | L | R | E | P | O | R | T | N | O | 0 | 3 | 2 | _____ (24) 26 | O | C | C | U | R | R | E | N | C | E | C | O | D | E | 0 | 3 | _____ (28) 29 | R | E | P | O | R | T | T | Y | P | E | L | _____ (30) | R | E | V | I | S | I | O | N | 0 | _____ (32)

18 | B | 18 | 19 | Z | 19 | Z | 20 | Z | 21 | 0 | 0 | 0 | 0 | 22 | 0 | 0 | 0 | 0 | 23 | N | 23 | N | 24 | N | 25 | W | 2 | 9 | 0 | 26 | _____
33 34 35 36 37 38 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | Investigation revealed a damaged lead in speed control unit. Lead was _____
1 1 | repaired, Emergency Feedwater Pump, 2P7A, restored to service as required _____
1 2 | by Action Statement T.S.3.7.1.2. _____
1 3 | _____
1 4 | _____

1 5 | B | 28 | 0 | 0 | 3 | 29 | Power Ascension | A | 31 | NA | _____ (32) DISCOVERY DESCRIPTION
7 8 9 10 12 13 44 45 46

1 6 | Z | 33 | Z | 34 | NA | _____ (35) AMOUNT OF ACTIVITY | NA | _____ (36) LOCATION OF RELEASE
7 8 9 10 11 44 45 80

1 7 | 0 | 0 | 0 | 37 | Z | 38 | NA | _____ (39) PERSONNEL EXPOSURES
7 8 9 11 12 13 80

1 8 | 0 | 0 | 0 | 40 | NA | _____ (41) PERSONNEL INJURIES
7 8 9 11 12 80

1 9 | Z | 42 | NA | _____ (43) LOSS OF OR DAMAGE TO FACILITY
7 8 9 11 12 80

2 0 | N | 44 | NA | _____ (45) PUBLICITY ISSUED
7 8 9 10 80

NAME OF PREPARER: Chris N. Shive y PHONE: 501/968-2519

7901310052