



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION I
631 PARK AVENUE
KING OF PRUSSIA, PENNSYLVANIA 19406

TERA

JAN 15 1979

Docket No. 70-1100

Combustion Engineering, Inc.
ATTN: Mr. H. V. Lichtenberger
Vice President - Nuclear Fuel
Nuclear Power Systems - Manufacturing
P. O. Box 500
Windsor, Connecticut 06095

Gentlemen:

Subject: Inspection 70-1100/78-10

This refers to your letter dated December 21, 1978, in response to our letter dated December 5, 1978.

Based upon a telephone conversation between Mr. G. Bakevich of your staff and Mr. D. Donaldson of this office on January 4, 1979, it is our understanding that, within 90 days, the ratios of the probe inlet velocities to the duct velocity will be determined for each of the nine absolute filtered ventilation systems to verify that each system exhibits a ratio within the range listed in Column 1, Table C 1, Appendix C, of ANSI N13.1-1969. If your intent differs from our understanding, please notify this office.

Thank you for informing us of the corrective and preventive actions documented in your letter. These actions will be examined during a subsequent inspection of your licensed program.

Your cooperation with us is appreciated.

Sincerely,

George H. Smith, Chief
Fuel Facility and Materials Safety
Branch

7902030003