

LICENSEE EVENT REPORT

CONTROL BLOCK

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

7	C	1		N	C	B	E	P	1	(2)	0	0	-	0	0	0	0	-	0	0	(3)	4	1	1	1	1	(4)			(5)		
	8	9	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	97	LAT		58

CON'T

0 1 8
REPORT SOURCE L 6 0 5 0 - 0 3 2 5 7 0 1 2 3 7 9 8 0 2 2 1 7 9 9
60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES

During the Standby Liquid Control (SLC) Relief Valve Test (P.T. 6.2.1), SLC relief

0	3	valve C41-F029 lifted at a pressure of 1300 psig. The Technical Specifications
---	---	--

0	4	require this valve to lift at 1400 \pm 50 psig.
---	---	---

05 (Technical Specification 3.1.5)

7 8 9 10 11 12 13 14 15 16 17 18 19 20

CODE CODE SUBCODE COMPONENT CODE SUBCODE SUBCODE

0 9 R B 11 E 12 X 13 V A L V E X 14 X 15 H 16

(17) LER NO. REPORT NUMBER: 79
 EVENT YEAR: 79
 SEQUENTIAL REPORT NO.: 002
 OCCURRENCE CODE: 03
 REPORT TYPE: L
 NO.: 0

ACTION TAKEN		FUTU' E ACTH		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS				ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER			
E	18	Z	19	Z	20	Z	21	0	0	0	0	Y	23	Y	24	N	25	L	2	6	5
33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1	0	Valve C41-F029 was disassembled and examined. No mechanical reason for failure was
---	---	--

found, and the valve was reassembled and reset after lapping and polishing of the

disc and seat. The valve was retested on 2/7/79 with the valve lifting at 1390 psig.

13 | This is considered an isolated event, and no further corrective action is required. |

FACILITY STATUS		% POWER			OTHER STATIONS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION		
1	5	H	28	0	0	0	29	NA	B	31	Periodic Test

ACTIVITY		CONTENT		RELEASED OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE	
1	6	7	13	2	34	NA		NA	

PERSONNEL EXPOSURES

NO.	NR	TYPE	DESCRIPTION
39			

PERSONNEL INJURIES
 (41)

NUMBER		DESCRIPTION	
1	8	0 0 0	40 NA
7	8	9	11 12

LOSS OF OR DAMAGE TO FACILITY

80

TYPE		DESCRIPTION	
1	9	Z	NA

ISSUED		DESCRIPTION		PUBLICITY	NRC USE ONLY
2	0	N	(44) NA		

7⁸9⁰ 22⁰7 0 342

NAME OF PREPARER A. C. Tollison, Jr.

PHONE: 919-457-6701