50-320

OFFICE OF INSPECTION AND ENFORCMENT
B&W SITE INSPECTOR DAILY REPORT

Davis-Besse Unit 1 (50-346)

Date: April 9, 1979
Inspector(s): T. Tambling
J. Smith

General Plant Status: Mode 5 (Cold Shutdown) Maintenance outage.

1. Summary of Licensee Response to IE Bulletin 79-05 and Supplements:

a. Review of Similar Transients (Item 2 of IEB 79-05A):

Licensee states that their review of transients is essentially complete. At this point they see no new information not already developed via the TMI-2 event.

b. Review and Revision of Operating and Maintenance Procedures (Items 3, 4, 5, 7, 8, 9, 10 of IEB 79-05A):

Revision to procedures is in progress, licensee expects to have job done by April 10, 1979. Emergency, Administrative and Maintenance procedures are being revised. A major change will be key control of ESF valves which was initiated prior to the TMI-2 event.

c. Review and Implementation of Changes in Containment Isolation (Item 6 IEB 79-05A):

No change in status; reference report of April 7, 1979.

d. Training of Plant Personnel (Items 1, 4, 11 and plant/procedures changes):

No change in status; reference report of April 7, 1979.

2136 050

7906290644

Genl 1120
4/9