OFFICE OF INSPECTION AND ENFORCEMENT
B&W SITE INSPECTOR DAILY REPORT

Site Rancho Seco

Date 4/13/79

Inspector(s) A. Johnson
L. Miller

General Plant Status: 100% Power - No known problems.

1. SUMMARY OF LICENSEE RESPONSE TO IE BULLETING 79-05 AND SUPPLEMENTS:

a. Review of Similar Transients (Item 2 of IEB 79-05A):

Completed (as specified in 4/12/79 report).

b. Review and Revision of Operating and Maintenance Procedures (Items 3, 4, 5, 7, 8, 9, 10 of IEB 79-05A):

Same as stated in 4/11/79 report; in addition, licensee is drafting a letter requesting clarification regarding item 4 of Bulletin 79-05A.

c. Review and Implementation of Changes in Containment Isolation (Item 6 IEB 79-054A):

Completed (as specified in 4/10/79 report).

d. Training of Plant Personnel (Items 1, 4, 11 and plant/procedures changes):

Same as reported in 4/12/79 report.

2164 057

7906290153

2. SUMMARY OF NRC INSPECTION ACTIVITY DURING PERIOD 4/12/79
(Address Items 1.a. thru 2.d. above, plus other independent/significant effort, identify shifts on which activity was done during past 24 hours):

Inspection coverage 5:00 AM to 6:00 PM. Inspection coverage included: Control room surveillance; verified accuracy of Containment Isolation Valve Lineup Procedures with P&ID's which completed TI 2595/02, item III.C.1; completed items III.C.3 and III.C.6; 50% complete on item III.C.8. Remainder of items in progress with expected completion by 0800 on 4/16/79.

3. STATUS OF INSPECTOR DISCUSSIONS WITH PLANT PERSONNEL:

Same as reported in 4/12/79 report.

4. DESCRIPTION OF GENERAL PLANT STATUS (i.e., operating power level, planned changes, scheduled outages, ESF out of service, major maintenance, reportable occurences, etc.)

100% power, next scheduled outage is in May 1979. No ESF systems out of service, no major maintenance. No planned changes in power level.

Summary of TI 2595/02 Items Completed to Date:

III.B - Completed except for three operators at Lynchburg.
III.C.1, 2, 3 and 6 - Complete.
III.C.8 - 50% Complete.
V - Complete except for three operators at Lynchburg.