NRC Research and Technical Assistance Report

INTERIM REPORT

6-5-79

Accession No.

Contract Program or Project Title:

Subject of this Document:

"Inhalation Dosage Determination Resulting from BST Failure and from Release Directly to the LOFT Containment Following L2-3 Blowdown"

Type of Document:

Author(s):

R. S. Schofield

Date of Document:

January 1979

Responsible NRC Individual and NRC Office or Division:

G. D. McPherson

This document was prepared primarily for preliminary or internal use. It has not received full review and approval. Since there may be substantive changes, this document should not be considered final.

H. P. Pearson, Supervisor Information Processing EG&G Idaho, Inc.

Prepared for U.S. Nuclear Regulatory Commission Washington, D.C. 20555

NRC Fin #A6048

INTERIM REPORT

NRC Research and Technical Assistance Report

2146 253



FORM FGAG 454 (Rev 9 75)

INTEROFFICE CORRESPONDENCE

NO. R-4291

date	 B	0 2	1979

to DISTRIBUTION

subject

from

DOCUMENT TRANSMITTAL

LOFT CDCS, TAN 602, Ext. 6177 S. X. Harkeway

The following documents released by LCrT CDCS, are hereby transmitted for your use and information:

DOCUMENT NO.			CHG.	DATE
LTR 10-51		Ø		1-16-79
"Inhalation Dos	age Determination Re	esulting from	m BST I	Failure and
from Release Di	rectly to the LOFT (Containment	Follow	ing 12-3
Blowdown"	R. S. Schofield			

M. I. McKnight

C. A. Moore

G. Sonneck

G. Stouz

W. A. Spencer

T. F. Pointer

L. O. Saukkoriipi

G. D. McPherson

N. E. Pace w/o Att.

J. C. Stachew w/o Att.

REMARKS: No dispositon required.

Distribution

W. Amidei B. O. Anderson E. C. Anderson w/o Att. J. G. Arendts G. A. Dinneen GT D. B. Engelman B. L. Freed Orig. + 7 R. C. Gottula R. C. Guenzler J. C. Haire K. Hofmann G. L. Hunt w/o Att. F. K. Hyer w/o Att. N. C. Kaufman w/o Att. J. P. Kester J. L. Liebenthal A. S. Lockhart D. W. Marshall

NRC Research and Technical Assistance Report O. R. Meyer w/o Att.

C. R. Toole L. Winters C. H. Cooper

K. Tasaka - 2

R. E. Tiller

- S. K. Hathaway 2
- R. S. Schofield

S. Matovich

LOFT TECHNICAL REPORT LTR 10-51 JANUARY 16, 1979

P394

INHALATION DOSAGE DETERMINATION RESULTING FROM BST FAILURE AND FROM RELEASE DIRECTLY TO THE LOFT CONTAINMENT FOLLOWING L2-3 BLOWDOWN



EGEG Idaho, Inc.

LOFT TECHNICAL REPORT

FORM EG&G-229 (Rev. 12-76)

· · · ·

INHALA	TION DOSAGE DETERMINATION RESULTING FROM BST FA	AILURE AND LTR 10-51
ROM R	ELEASE DIRECTLY TO THE LOFT CONTAINMENT FOLLOW	ING L2-3 BLOWDOWN
UTHOR C. S. ERFORMINATION	Schofield NG ORGANIZATION Division	52191-100-300
OFT APP	offine Selfer	January 16, 1979
Sup Th do	is LTR presents results obtained from analyses sages following L2-3 blowdown. Two events were	to scope potential radiological considered by these analyses:
(1 hea Blo the) inhalation dose at the site boundary assumin ader failure and (2) inhalation dose at the on owdown Suppression Tank integrity failure. Bot e following assumptions:	ng Blowdown Suppression Tank ne-mile fence following ch events were evaluated using
1.	Releases were examined for L2-3 operating tim hours at 37.2 MW.	nes of 20, 40, 100, and 1,000
2.	Of the core's fuel rods, 20% were perforated of the core iodine fission inventory (FPI).	during blowdown releasing 11%
	a. The entire 11% iodine inventory was exhau	sted to the PCS.
3.	The leak rate from containment was considered pressure and temperature, as described in LOF Appendix 6-E, and Volume 2, Chapter 13, Append	to be a function of the CV T FSAR Volume 1, Chapter 6, dix 13-A.
4;	Class F (2 meters per second windspeed) meter used to determine isotopic air concentrations	orological conditions were at the location of inhalation.
5.	Breathing rates were 1.25 m^3/hr for inhalation hours at the one-mile exclusion fence and at the on	n times of one hour and eight the 10 m site boundary.
6.	Doses were calculated for an adult thyroid (i.	.e., 20 gm mass).
Α.	Analysis 1	
	Analysis 1 was performed to indicate the maxim could specifically result from the L2-3 test. containment due to BST header failure. The pr (extremely unlikely) during a LOCE requires th Damage Criteria D (7.2R) inhalation dose at th	mum radiological exposure which Blowdown was directed to the robability of this event he consequence of the event to mee he site boundary (10 ⁴ meters).

LTR 10-51 Page 2

B. Analysis 2

Analysis 2 was performed to evaluate the radiological exposure which could specifically result from the L2-3 test assuming BST integrity failure at the time of blowdown. The consequences of this event are less than Damage Criteria C-1 (ERDAM 0524 limit at the one mile fence); namely 1.5 Rem.

- NOTE: 1. The pressure time history of this transient indicates no driving pressure inside the containment after 8 hours.
 - These analyses have received independent safety review thru the EG&G Safety Division Ref. DPH-217-78 letter.

2146 257

LTR 10-51



cc: J. L. Clark J'c J. G. Collett J. W. McCaslin H. K. Peterson J. F. Sommers Central File R. S. Schofield File

INTEROFFICE CORRESPONDENCE

September 25, 1978 date

C. H. Cooper to

trom

R. S. Schofield R. S Schopield

- Subject IODINE INHALATION DOSAGE DETERMINATION FROM A MAXIMUM HYPOTHETICAL PRIMARY COOLANT SYSTEM RELEASE ACCIDENT FOLLOWING L2-3 - RSS-10-78
- Ref: R. S. Schofield ltr to C. H. Cooper, RSS-8-78, Inhalation Dosage Determination From A Blowdown Suppression Tank (BST) Relief Valve Rupture Following L2-3, July 25, 1978

An analysis has been performed to determine the inhalation dose at the one-mile exclusion fence and at the site boundary as a result of a maximum hypothetical accident (MHA) primary coolant system (PCS) containment vessel release following L2-3. The RSAC-II computer code[1] was used to verify the iodine thyroid dose (considered as the dominant hazard in a containment release $\begin{bmatrix} 2 \\ - \end{bmatrix}$ for inhalation times of one hour and eight hours. The following assumptions used in this study should be examined carefully for complete understanding of this analysis and the parameters it is dependent upon.

Assumptions:

- 1. Releases were examined for L2-3 operating times of 20, 40, 100, and 1,000 hours at 37.2 MW.
- 2. Of the core's fuel rods, 20% were perforated during blowdown. releasing 11% of the core iodine fission product inventory (FPI).
 - a. The entire 11% iodine inventory was evausted to the PCS.
- The PCS ruptured immediately following slowdown, releasing 3. all of the iodines to the containmen' vessel (CV) (i.e., no water filtration of elemental iod; e assumed).
 - L2-3 blowdown was performed in a containment isolation a. mode, therefore no CV atmospheric clean-up was considered.
 - b. No iodine plate-out was considered during the PCS release to containment.
- 4. The leak rate from containment was considered to be a function of the CV pressure and temperature, as described in LOFT FSAR Volume 1, Chapter 6, Appendix 6-E, and Volume 2, Chapter 13, Appendix 13-A.

2146 258

C. H. Cooper RSS-10-78 September 25, 1978 Page 2

- Class F (2 metres per second windspeed) meteorological conditions were used to determine isotopic air concentrations at the location of inhalation.
- Breathing rates were 1.25 m³/hr for inhalation times of one hour and eight hours at the one-mile exclusion fence and at the 10⁴ m site boundary.
- 7. Doses were calculated for an adult thyroid (i.e., 20 gm mass).

Tables I and II reveal the isotopic and total iodine inhalation dose to the thyroid for the previously-mentioned conditions. Isotopic radioactive decay during transit to the inhalation point was considered in the calculations. It is interesting to observe that, for the operating times specified (20, 40, and 100 hours), the iodine-131 thyroid dose is significantly lower than the dose contribution from iodine-133. Traditionally, the literature[²] states the iodine-131 dose contributes approximately 65% of the total thyroid dose, while iodine-133 contributes approximately 30%. These iodine ratios appear to be valid only after operating times approaching 1,000 hours.

TABLE I

	REA			
	20 Hours	40 Hours	100 Hours	1000 Hours
VERMIT EL DELL'ERTE	an nadaratik akadara	One-Mile Excl	usion Fence	
1311	7.5 (18%)	12.6 (21%)	26.7 (32%)	85.4 (59%)
1331	26.4 (64%)	37.7 (65%)	48.1 (58%)	49.7 (34%)
Total Iodine Thyroid Dose	41.1	58.7	83.9	145.3
		Site Boundary	(10 ⁴ m)	
1 3 1 I	1.2 (17%)	2.0 (21%)	4.2 (31%)	13.5 (58%)
1331	4.6 (67%)	6.3 (66%)	7.9 (58%)	8.1 (35%)
Total Iodine Thyroid Dose	6.9	9.6	13.6	23.3
and the second				the second s

ONE-HOUR INHALATION THYROID DOSLS* FOLLOWING L2-3 MHA PCS RELEASE

* All units in mrem.

C. H. Cooper RSS-10-78 September 25, 1978 Page 3

TABLE II

EIGHT-HOUR INHALATION THYROID DOSES* FOLLOWING L2-3 MHA PCS RELEASE

	REACTOR OPERATING TIMES (at 37.2 MW)				
	20 Hours	40 Hours	100 Hours	1000 Hours	
		One-Mile Excl	usion Fence	R	
^{1 3 1} I	35.5 (18%)	61.7 (22%)	132.0 (33%)	417.1 (59%)	
^{1 3 3} I	137.6 (69%)	188.2 (66%)	234.5 (57%)	242.2 (34%)	
Total Iodine Thyroid Dose	202.2	285.9	410.5	714.6	
26.17		Site Boundary	(10 ⁴ m)		
^{1 3 1} I	5.7 (19%)	9.9 (23%)	21.0 (33%)	65.7 (59%)	
1331	21.8 (69%)	29.4 (66%)	36.5 (56%)	37.6 (33%)	
Total Iodine Thyroid Dose	31.0	44.6	64.2	112.1	

* All units in mrem.

The ingestion dose to a child's thyroid has been estimated at 400 times the iodine-131 and 20 times the iodine-133 adult inhalation thyroid dose[³]. Table III represents the child thyroid ingestion dose based upon the eighthour adult inhalation thyroid dose at the site boundary.

2146 260

C. H. Cooper RSS-10-78 September 25, 1978 Page 4

TABLE III

CHILD) THYROID 1	INGESTIC	IN DOSE	S* AT THE	SITE BOUNDARY
	FOLLOWING	L2-3 MH	IA PCS	EIGHT-HOUR	RELEASE

	REACTOR OPERATING TIMES (at 37.2 MW)				
	20 Hours	40 Hours	100 Hours	1000 Hours	
131 [** Contribution	2.28	3.95	8.40	26.30	
1331** Contribution	0.44	0.59	0.73	0.75	
Total Child Thyroid Dose	2.72	4.54	9.13	27.05	

* All units in rem.

** ¹³¹I inhalat on dose x 400; ¹³³I inhalation dose x 20.

The 100-hour and 1,000-hour reactor operating times in Table III exceed maximum hypothetical Class D accident child thyroid dose limits["] (2 rem/yr) by factors of 1.3 and 3.8.

Since maximum permissible air concentrations and thyroid ingestion dose limits are exceeded, potential emergency actions associated with these conditions would include evacuation of controlled-area personnel and restriction of milk suppliers from local dairy farms[²]. These procedures are not intended to represent the extent of emergency planning accompanying such a release. Further analysis is needed to determine a compretensive emergency planned response.

Material contained in these calculations falls under the nature of "safety analysis"; therefore, any direct or indirect use of this material in documents for distribution outside the company will require review by the Safety Division.

mab

- [1] D. R. Wenzel, Preliminary User's Manual For The Revised Radiological Safety Analysis Coumputer Program (RSAC-II), Allied Chemical Corporation, (June, 1973)
- [2] J. R. Beattie, An Assessment Of Environmental Hazard From Fission Product Releases, United Kingdom Atomic Energy Authority, (1963)
- [3] G. A. Dinneen, Offsite Thyroid Exposures From Isolation Valve Leakage, LTR-128-2, (November, 1970)
- [*] LOFT FSAR, Volume 3, Chapter 15, Section 15.5.1.3.1

2146 261

LTR 10-51



cc: B. R. Baldwin J. L. Clark J. G. Collett G. A. Dinneen D. W. Marshall H. K. Peterson

J. F. Sommers Central File

R. S. Schofield File

INTEROFFICE CORRESPONDENCE

date November 14, 1978

C. H. Cooper to

R. S. Schofield RSSchifted from

Subject IODINE INHALATION DOSAGE DETERMINATION FROM A BLOWDOWN SUPPRESSION TANK (BST) FAILURE FOLLOWING L2-3 - RS5-13-78

- Ref: (a) R. S. Schofield ltr to C. H. Cooper, RSS-8-78, Inhalation Dosage Determination From A Blowdown Suppression Tank (BST) Relief Valve Rupture Following L2-3, July 25, 1978
 - (b) R. S. Schofield ltr to C. H. Cooper, RSS-10-78, Iodine Inhalation Dosage Determination From A Maximum Hypothetical Primary Coolant System Release Accident Following L2-3, September 25, 1978

A follow-up analysis to RSS-10-78 has been erformed to determine the inhalation dose at the one-mile exclusion ance and at the site boundary as a result of a BST relief valve rupture containment vessel release following L2-3. The RSAC-II computer code[1] was used to verify the iodine thyroid dose (considered as the dominant hazard from a containment release[2]) for inhalation times of one hour and eight hours. The following assumptions used in this study should be examined carefully for complete understanding of this analysis and the parameters it is dependent upon.

Assumptions:

- Releases were examined for L2-3 operating times of 20, 40, 1. 100, and 1,000 hours at 37.2 MW.
- 2. Of the core's fuel rods, 20% were perforated during blowdown. releasing 11% of the core iodine fission product inventory (FPI).
 - The entire 11% iodine inventory was exhausted to the a . primary coolant system (PCS) and then to the BST at blowdown.
- 3. The BST relief valve ruptured immediately following blowdown, releasing all of the iodines to the containment vessel (CV) (i.e., no water filtration of elemental iodine is assumed*).

* Iodine filtration in water has been estimated as high as 90%, but, due to the difficulty in defining a filtration fraction at blowdown, the iodine scrubbing was ignored.

2146 262

C. H. Cooper RSS-13-78 November 14, 1978 Page 2

- a. L2-3 blowdown was performed in a containment isolation mode, therefore no CV atmospheric clean-up was considered.
- b. Of the iodine released to containment, 50% was assumed to plate out on the mobile test assembly (MTA) and inner surfaces of the CV (USNRC Regulatory Guide 1.4).
- The leak rate from containment was considered to be a function of the CV pressure and temperature, as described in LOFT FSAR Volume 2, Chapter 13, Appendix 13-A.
 - a. A conservative maximum CV pressure of 17.0 psia* was assumed to develop following the BST relief valve rupture.
- Class F (2 metres per second windspeed) meteorological conditions were used to determine isotopic air concentrations at the location of inhalation.
- Breathing rates were 1.25 m³/hr for inhalation times of one hour and eight hours at the one-mile exclusion fence and at the 10⁴ m site boundary.
- 7. Doses were calculated for an adult thyroid (i.e., 20 gm mass).

Tables I and II reveal the isotopic and total iodine inhalation dose to the thyroid for the previously-mentioned conditions. Isotopic radioactive decay during transit to the inhalation point was considered in the calculations.

It is interesting to observe that, for the operating times specified (20, 40, and 100 hours), the iodine-131 thyroid dose is significantly lower than the dose contribution from iodine-133. Traditionally, the literature[²] states the iodine-131 dose contributes approximately 65% of the total thyroid dose, while iodine-133 contributes approximately 30%. These iodine ratios appear to be valid only after operating times approaching 1,000 hours.

* Conservative estimation as specified by C. H. Cooper, LOFT Protection & Control Systems. C. H. Cooper RSS-13-78 November 14, 1978 Page 3

TABLE I

ONE-HOUR NHALATION THYROID DOSES* FOLLOWING L2-3 BST RELIEF VALVE RUPTURE

* All units in mrem.

	REACTOR OPERATING TIMES (at 37.2 MW)				
	20 Hours	40 Hours	100 Hours	1000 Hours	
		One-Mile Exclu	sion Fence	t [.]	
131I	3.4	5.2	10.2	30.7	
133I	11.3	15.2	18.1	19.4	
Total Iodine Thyroid Dose	17.6	23.9	33	54.6	
		Site Boundary	(10 [*] m)		
131I	0.6	0.9	1.6	4.9	
1 3 3 I	2.1	2.7	3.3	3.4	
Total Iodine Thyroid Dose	3.1	4.1	5.6	9.1	

TABLE II

EIGHT-HOUR INHALATION THYROID DOSES* FOLLOWING L2-3 BST RELIEF VALVE RUPTURE

* All units in mrem.

percent of the second se						
	REACTOR OPERATING TIMES (at 37.2 MW)					
	20 Hours	40 Hours	100 Hours	1000 Hours		
		One-Mile Exclu	sion Fence	the second second second		
1 3 1 I	16.4	26.3	52.1	130.6		
1 3 3 I	65.3	83.5	100.0	102.6		
Total Iodine Thyroid Dose	94.4	126.1	174.0	286.7		
		Site Boundary	(10 ⁴ m)			
¹³¹ I	2.7	4.3	8.4	24.4		
^{1 3 3} I	10.7	13.3	15.8	16.2		
Total Iodine Thyroid Dose	15.1	20.0	27.7	45.6		
		0				

C. H. Cooper RSS-13-78 November 14, 1978 Page 4

The inhalation doses in Tables I and II comply with the radiological consequence levels as specified by LOFT Technical Specification 3.13, "Damage Criteria."

The ingestion dose to a child's thyroid has been estimated at 400 times the iodine-131, and 20 times the iodine-133, adult inhalation thyroid dose[³]. Table III represents the child thyroid ingestion dose based upon the eight-hour adult inhalation thyroid dose at the site boundary.

TABLE III

CHILD THYROID INGESTION DOSES* AT THE SITE BOUNDARY FOLLOWING L2-3 BST RELIEF VALVE RUPTURE EIGHT-HOUR RELEASE

비난 이 사람	SFACTOR OPERATING TIMES (at 37.2 MW)				
	20 Hours	40 Hours	100 Hours	1000 Hours	
¹³¹ I** Contribution	1.08	1.72	3.35	7.76	
133I** Contribution	0.21	0,27	0.32	0.32	
Total Child Thyroid Dose	1.29	1.99	3.67	10.08	

* All units in rem.

** ¹³¹I adult inhalation dose x 400; ¹³³I adult inhalation dose x 20.

The 40-, 100-, and 1,000-hour reactor operating times in Table III exceed the ERDAM 0524 thyroid yearly dose commitment of 1.5 rem. However, due to the conservative nature of Assumptions 3 and 4a of this analysis, it is not likely the ingested dose rates would yield a thyroid dose in excess of the 1.5 rem limit.

Material contained in these calculations falls under the nature of "safety analysis"; therefore, any direct or indirect use of this material in documents for distribution outside the company will require review by the Safety Division.

mab

LTR 10-51

C. H. Cooper RSS-13-78 November 14, 1978 Page 5

. . .

- [1] D. R. Wenzel, Preliminary User's Manual For The Revised Radiological Safety Analysis Computer Program (RSAC-II), Allied Chemical Corporation, (June, 1973)
- [²] J. R. Beattie, An Assessment Of Environmental Hazard From Fission Product Releases, United Kingdom Atomic Energy Authority, (1963)
- [³] G. A. Dinneen, Offsite Thyroid Exposures From Isolation Valve Leakage, LTR-128-2, (November, 1970)