



NERC

NORTH AMERICAN ELECTRIC
RELIABILITY CORPORATION

2019 State of Reliability Report

Mark G. Lauby
Senior Vice President and Chief Engineer

RELIABILITY | ACCOUNTABILITY



Key Findings and Recommendations

- High Reliability in 2018, No Non-Weather Category 3, 4, or 5 events
 - Hurricane Michael and Florence Category 3
- Extreme weather events continue to be leading contributor to the largest generation and distribution outages
- Better than expected performance from Texas generation fleet helped meet 2018 summer peak demand; reliability risk in 2019 due to continued capacity deficit
- Continued downward misoperation rate trend
- Improving or stable frequency response performance in all interconnections
- Emerging reliability challenges identified as more inverter-based generation is added

NERC

NORTH AMERICAN ELECTRIC
RELIABILITY CORPORATION

By The Numbers

4,353,740,908 MWh

2018 Actual Energy

1,028,629 MW

2018 Summer Peak Capacity

469,842 mi

Total Transmission Circuit Miles > 100kV

5,816

Number of Conventional Generating Units > 20MW

99.92%

Time with no operator-controlled
load shedding

0

Category 3, 4, or 5 Events
(non-weather related)

The ERO Enterprise: NERC and 7 Regional Entities



TEXASRE

MPCC, Inc.

WECC

15 Reliability Coordinators

4 Interconnections

184 Transmission Operators

991 Generator Owners

73 Balancing Authorities

398 Distribution Providers

Bulk Power System Situation Awareness Inputs and Products in 2018

233

DOE OE-417 Reports

459

EOP-004-3 Reports

2

EOP-002-3 Reports



2,963


Intelligent Alarms

4,239

FNet Notifications

1,855

RCIS Messages



NERC BPS Situational Awareness



255

Daily Reports

5

Special Reports



0

Level 1 Alert

1

Level 2 Alerts

Event Analysis (2018, Trends, Causes)

Category 1

169

56 — 3 or more BPS facilities lost (1a)
7 — BPS SPS/RAS Misoperation (1c)
1 — Voltage reduction > 3% (1d)
3 — Unintended loss 1,000-1,999MW in ERCOT (1g)
102 — EMS (1h)

Category 2

6

4 — Unintended loss of load (2f)
2 — IROL Violation

Category 3

2


Hurricane Michael
Hurricane Florence

Category 4


0

Category 5

0



- Design/Engineering
- Management/Organization
- Equipment/Material
- Training
- Other
- Individual Performance
- Communication



2014-2018 Event Analysis Trends

2014-2018 Event Analysis Trends




856 Event Reports

378 Identified Root Causes




116 MW


Overall (Five-Year) Average Load Loss of
Non-Weather Driven Events with Load Loss



Number of Non-Weather Events with
Load Loss and Annual Average Load Loss




- Management/Organization
- Design/Engineering
- Equipment/Material
- Other
- Communication
- Individual Performance
- Training
- No Causes Found
- Overall Configuration



2014-2018 Identified Root Causes
(Processed to-date)

Total Category 1 Events by Year and
Subcategory




NERC

NORTH AMERICAN ELECTRIC
RELIABILITY CORPORATION


A stylized map of North America, including the United States, Canada, and Mexico, rendered in shades of blue and white. The map is positioned behind a horizontal blue band that contains the title.

Reliability Indicators


Reliability Indicator – Transmission Related Events Results in Loss of Load



Reliability Indicator – Protection System Misoperation Rate




**Annual Protection System
Misoperation Rate**




**Five-Year Protection System
Misoperation Rate by Region**

Q4 2013 through Q3 2018


Severity Risk Index



Severity Risk Index (SRI) - Sorted



Severity Risk Index (SRI) – Cumulative




BPS Planning and Adapting to a Changing Resource Mix


- Concerns with inverter-based resource persist and mitigation strategies are being developed by the NERC Inverter-Based Resources Task Force.
- NERC Alert helped inform industry of the vulnerabilities associated with momentary cessation.

NERC Alert 1


Susceptible to Erroneous Frequency Calculations?



Inverter cease output during abnormal voltages?



NERC Alert II



Recommendations

The ERO and Industry should:

1 - Continue improving their ability to understand, model, and plan for a system with a significantly different resource mix. Priority should be given to:

- Frequency response under low inertia conditions
- Contributions of inverter-based resources to essential reliability services
- Increasing protection system and restoration complexities with increased inverter-based resources
- Resource adequacy with increasing energy constraints

2 - Develop comparative metrics to understand the different dimensions of resilience during extreme events and system performance changes over time.

3 - Better understand and share information on cyber and physical security threats and mitigate the risks through a variety of approaches, including resilient system design, consequence-informed planning and operation, and practicing response and recovery processes.

NERC


NORTH AMERICAN ELECTRIC
RELIABILITY CORPORATION

EMP Task Force Status Update

NRC


Mark Lauby, Senior Vice President and Chief Engineer

RELIABILITY | ACCOUNTABILITY



- **May 2019:** NERC launched a Task Force to identify reliability concerns associated with EMPs and potential methods for promoting resilience
- The Task Force advises NERC, regulators, Regional Entities, and industry stakeholders to establish a common understanding of the scope, priority, and goals for the **development of next-steps to address resilience to HEMP events**

EMP Task Force: Phased Approach



- The Task Force has broken up the topic of EMP as it relates to the utility industry in the following categories:
 - **Policy** – What needs to be clearly defined by industry and federal government
 - **Research** – What research is needed to prudently inform utilities that need to make decisions
 - **Vulnerability Assessments** – How does the utility industry take the policy and research to understand its vulnerability
 - **Mitigation Guidelines** – Fundamental suggestions and guidelines on prudent mitigation strategies
 - **Response and Recovery** – Based on the vulnerability assessments and any mitigation guidelines, for any impacted facilities, how does a utility respond and recover

NERC

NORTH AMERICAN ELECTRIC
RELIABILITY CORPORATION

A stylized map of North America, including the United States, Canada, and Mexico, rendered in shades of blue and white. The map is positioned in the background, with a horizontal blue band across the middle containing the title.

Questions and Answers