

DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

WILLIAM O. PARKER, JR.  
VICE PRESIDENT  
STEAM PRODUCTION

February 1, 1979

TELEPHONE: AREA 704  
373-4083

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Attention: Mr. Robert L. Baer  
Light Water Reactors  
Project Branch No. 2

Subject: McGuire Nuclear Station  
Docket Nos. 50-369 and 50-370  
Preservice Inspection Plan


Dear Mr. Denton:

Your letter of April 26, 1978 transmitted questions 121.15 and 121.16 requesting additional information with regard to the McGuire Unit No. 1 preservice inspection plan. Our response to this request was transmitted by a May 31, 1978 letter to Mr. Edson G. Case. After further discussions with members of the NRC staff Duke provided more detailed request for relief from ASME Section XI requirements. These requests for relief are summarized in Attachment 1.

Attachment 2 consists of requests for relief MC-1-025 through MC-1-031. MC-1-025 and MC-1-026 complete the known requests for relief from ASME Class II requirements. Requests for relief MC-1-027 through MC-1-031 are further requests for relief from ASME Class I and Class II requirements which supplement our May 31, 1978 letter.

It is requested that requests for relief MC-1-014 and MC-1-015, transmitted by our July 24, 1978 letter, be withdrawn. It has been determined that there are no welded supports on Class I systems thus making MC-1-014 and MC-015 unnecessary.

Very truly yours,

  
William O. Parker, Jr.

GJP:scs  
Enclosure

BOOK  
S/E  
11

7902060236i

Q

ATTACHMENT 1  
Relief Request Summary

<u>Date Of Submittal</u>	<u>Relief Serial No.</u>	<u>Code Class</u>	<u>Description of Component/Relief</u>
July 24, 1978	MC-1-001	N/A	Request for relief from requirement of ASME Boiler & Pressure Code Section V, 1971 Edition thru Winter 1972 Addenda. Article 6, Paragraph T-630.
"	MC-1-002	I	Reactor vessel primary nozzle to safe-end welds.
"	MC-1-003	I	Pressurizer Longitudinal and Circumferential weld seams-National Board Number 68-123.
"	MC-1-004	I	Pressurizer integrally welded supports-National Board Number 68-123.
"	MC-1-005	I	Steam Generator Circumferential weld seams-National Board Nos. 1A: 68-107, 1B: 68-108, 1C: 68-109, 1D: 68-110
"	MC-1-006	I	Steam Generator Nozzle to safe-end welds-National Board Nos. same as MC-1-005.
"	MC-1-007	I	Pressurizer safe-end to surge line-National Board No. 68-213.
"	MC-1-008	I	Piping-Longitudinal and Circumferential weld seams.
"	MC-1-009	I	Branch piping welds exceeding 4 inches (NPS) - Visual Inspection impractical.
"	MC-1-010	I	Branch piping welds exceeding 4 inches (NPS) - 4 inch NPS changed to 6 inch NPS.
"	MC-1-011	I	Branch Piping Welds 4 inch (NPS) & smaller - Visual Inspection impractical.
"	MC-1-012	I	Branch Piping Welds 4 inch (NPS) & smaller - 4 inch NPS to 6 inch NPS
"	MC-1-013	I	Piping Socket Welds
"	MC-1-014	I	Piping Integrally Welded Supports
"	MC-1-015	I	Valve Integrally welded Supports
"	MC-2-001	N/A	Same as MC-1-001
September 5, 1978	MC-1-016	I, II	All components requiring preservice hydrostatic test.
"	MC-1-017	I	ASME Class I valves $\geq$ 3 inches (NPS)
September 25, 1978	MC-1-018	I	Reactor Coolant Pumps 1A, 1B, 1C, 1D
"	MC-1-019	I	Reactor Coolant Pumps 1A, 1B, 1C, 1D Lower Seal Housing Belts (12 per pump)

## ATTACHMENT 1

Page Two

## Relief Request Summary

<u>Date Of Submitted</u>	<u>Serial No.</u>	<u>Code Class</u>	<u>Description of Component/Relief</u>
September 25, 1979	MC-1-020	I	Reactor Coolant Pumps 1A, 1B, 1C, 1D Lower Seal Housing Ligament Area
"	MC-1-021	I	Reactor Vessel Head, Control Rod Drive Penetrations - National Board No. 20766
"	MC-1-022	I	Reactor Vessel Incore Instrument Penetrations - National Board No. 20766
"	MC-1-023	I	Control Rod Drive Mechanisms Housing Welds
"	MC-1-024	I	Reactor Vessel Closure Head-National Board No. 20766

Mr. Harold R. Denton, Director  
February 1, 1979

DUKE POWER COMPANY

Requests For Relief From  
Inservice Inspection Requirement  
McGuire Nuclear Station

ATTACHMENT 2

DUKE POWER COMPANY  
Request For Relief From  
Inservice Inspection Requirement

Station: McGuire

Unit: 1

Reference Code: ASME Boiler and Pressure Vessel Code, Section XI, 1971 Edition  
through Winter 1972 Addenda

- I. Component for which exemption is requested:
- Name and Identification Number:  
Residual Heat Removal (ND) Heat Exchangers (2)  
National Board Numbers 635, 636
  - Function:  
Primary Coolant Heat Removal
  - ASME Section III Code Class:  
Class II
  - Valve Category: NA
- II. Reference Code Requirement that has been determined to be impractical:  
Category C-B Item C1.2 Volumetric examination of nozzle to vessel welds  
(2 per heat exchanger). Due to welded collar, the nozzle to vessel welds  
are inaccessible. See attachment I.
- III. Basis for Requesting Relief
- Material - Shell SA-240 Type 304 SS, Nozzles SA312 Type 304SS  
Estimate of preservice examination performed - 0%  
Original fabrication examination - Radiography and dye penetrant examination  
Measures which would be required to make the area accessible - Removal of  
the welded collars  
Reference Drawing - Sketch Attached

DUKE POWER COMPANY

Request For Relief From  
Inservice Inspection Requirement

III. Basis for Requesting Relief (cont.)


To grind off the welded collars would not justify the high cost and loss of time to inspect the nozzle to vessel welds. The shop examinations provide adequate assurance of component reliability.

IV. Alternate Examination:

The fillet welds attaching the collar to the nozzle and shell will be examined with dye penetrant. The vessel has been hydrostatically tested with no evidence of leakage.

V. Implementation Schedule:

Inservice inspections will include a surface examination of the collar welds and hydrostatic tests.



ND Heat Exchanger  
Inaccessable Nozzle Welds

DUKE POWER COMPANY  
Request For Relief From  
Inservice Inspection Requirement

Station: McGuire

Unit: 1

Reference Code: ASME Boiler & Pressure Vessel Code, Section XI, 1971  
Edition through Winter 1972 Addenda

I. Component for which exemption is requested:

a. Name and Identification Number:

Steam Generators 1A, 1B, 1C, 1D  
National Board Numbers 68-107, 68-108, 68-109, 68-110 respectively

b. Function:

Primary to Secondary coolant heat exchanger

c. ASME Section III Code Class:

Class II

d. Valve Category: NA

II. Reference Code Requirement that has been determined to be impractical:  
Category C-A Item CI.1 of Table ISC-261 volumetric examination of  
steam generator transition cone to lower shell barrel circumferential  
weld. Due to location of seismic restraint, approximately 60% of the  
weld is obscured.

III. Basis for Requesting Relief

Material - ASME-SA-533, Grade A Class 2

Estimate of preservice examination performed - 40%

Original fabrication examination - Radiography

Measures which would be required to make the area accessible - Removal  
of seismic restraint.

Reference Drawing - Sketch Attached



## DUKE POWER COMPANY

Request For Relief From  
Inservice Inspection Requirement

## III. Basis for Requesting Relief (cont.)


The welds in question have been ultrasonically tested from one side using 0°, 45°, and 60° transducers. Due to the location of the restraint, it is impossible to perform the 0° scan on the weld centerline or the 45° and 60° scans from the lower side of the weld. All other steam generator welds are accessible. It is believed that the limited scan plus the periodic hydrostatic tests provide adequate assurance of weld integrity. The high cost in time and money does not justify relocating the seismic restraint.

## IV. Alternate Examination:

None

## V. Implementation Schedule:

Inservice inspections will be performed by using the limited scan described above.



Steam Generator  
(Typical of 4)

DUKE POWER COMPANY  
Request For Relief From  
Inservice Inspection Requirement

Station: McGuire

Unit: , 1

Reference Code: ASMS Boiler and Pressure Vessel Code, Section XI, 1971  
Edition through 1972 Winter Addenda

I. Component for which exemption is requested:

a. Name and Identification Number:

Steam Generators 1A, 1B, 1C, 1D  
National Board Numbers, 68-107, 68-108, 68-109, 68-110 respectively

b. Function:

Primary to Secondary coolant heat exchanger

c. ASME Section III Code Class:

Class I

d. Valve Category:

NA

II. Reference Code Requirement that has been determined to be impractical:

Category F Item 3.3 of Table IS-261 Volumetric examination of primary nozzle to safe-end welds. Due to presence of ground out areas and the contour of the nozzle, the safe-end weld cannot be fully inspected.

III. Basis for Requesting Relief

Material - ASME SA-216 Grade WCC casting, buttered with Type 309 austenitic stainless steel, welded to centrifugally cast ASME SA-351 CF8A stainless steel piping.

Estimate of Preservice Examination Performed - 90% volumetric, 100% surface  
Original Fabrication Examination - Radiography and liquid penetrant

Measures which would be required to make the area accessible - Cosmetic  
welding then post weld heat treatment

Reference Drawing - Sketch attached

## DUKE POWER COMPANY

Request For Relief From  
Inservice Inspection Requirement

## III. Basis for Requesting Relief (cont.)


The ground out areas are present on all eight nozzle to safe-end welds and vary in depth from 1/32 inch to 1/8 inch. As can be seen from the attached sketch, the ground-out areas only slightly limit the ultrasonic scan. Both the manufacturer and an outside consultant have recommended that cosmetic welding not be performed. Because of our concern that cosmetic welding might be deleterious to the weld joints, this request for relief is submitted.

## IV. Alternate Examination:

The welds have been examined ultrasonically, visually, and with dye penetrant in accordance with the Section XI Code.

## V. Implementation Schedule:

Inservice inspection will be performed in accordance with the Section XI Code Edition specified by 10CFR55.55 a, paragraph (g). In addition, the welds will be examined using liquid penetrant every third refueling outage.



Safe-End  
Buildup

Clad

— Acceptable  
UT Scan

- - - Limited UT  
Scan

Steam Generator  
Nozzle-to-pipe  
Safe-End Weld

DUKE POWER COMPANY  
Request For Relief From  
Inservice Inspection Requirement

Station: McGuire

Unit: 1

Reference Code: ASME Boiler and Pressure Vessel Code, Section XI, 1971 Edition  
through Winter 1972 Addenda.

I. Component for which exemption is requested:

a. Name and Identification Number:

Containment Penetration Assemblies:

Type I - Main Steam (4)	Type III-3 -RHR discharge to hot legs (1)
Type II - Feedwater (4)	Type III-5 - Upper Head Injection(2)
Type III-2 - RHR discharge to cold legs (2)	
Type III-3 - RHR supply (1)	

b. Function:

Provide air tight seal for piping through the containment boundary

c. ASME Section III Code Class:

Class II

d. Valve Category:

NA

II. Reference Code Requirement that has been determined to be impractical:

Categories C-F, C-G - Item C2.1 of Table ISC-261 volumetric examination of piping circumferential butt welds. Due to the design of the penetration assemblies, the penetration flued head to process pipe welds are inaccessible. In addition, the Type I and Type II penetration flued head to guard pipe welds are inaccessible.

III. Basis for Requesting Relief

Reference Drawings - See figures 1, 2, 3, 4 attached

Material - See figures 1, 2, 3, 4

Estimate of Preservice Examination Performed - 0% of the inaccessible welds

Original Fabrication Examination - Radiography, Type I (Main Steam) flued head to guard pipe welds received penetrant and ultrasonic examination  
Type II (feedwater) flued head to guard pipe welds were examined by radiography.

Measures which would be required to make the areas accessible - complete redesign, manufacture, and installation.

DUKE POWER COMPANY

Request For Relief From  
Inservice Inspection Requirement

III. Basis for Requesting Relief (cont.)


At the time of purchase, the penetration assemblies were state of the art in design and manufacturing technique. Redesign and replacement would result in extended delay and enormous cost. Component integrity can be assured with examination of similar welds in the process pipe coupled with hydrostatic tests and penetration leak tests.

IV. Alternate Examination:

Piping systems have been hydrostatically tested and penetrations will be leak tested.

V. Implementation Schedule:

Inservice inspection will consist of testing described in IV above.



Process Pipe:  
 31.5" I.D. x 1.250" Min. Wall  
 ASME SA-155 GR. KC-70


TYPE I (Main Steam)  
 4/Unit

Guard Pipe:  
 40" OD x 1.0" Min. Wall  
 ASME SA-155 GR KC-70

Flued Head:  
 ASME SA-105 GR 11

FIGURE 1





TYPE II (Feedwater)  
4/Unit


Process Pipe:

18" NPS S-80  
ASME SA-106 GR.B

Flued Head:

ASME SA-105 GR 11

FIGURE 2



REF: MC-1676-3.4

TYPE III - 2


(RHR Heat Exchanger  
Supply to Loop Cold Legs)

Process Pipe:  
8" NPS S-160  
ASME SA376 TP304 SS

Flued Head:  
ASME SA-182 GR F-304 SS

2/Unit

FIGURE 3



REF: MC-1676-3.4

Process Pipe:

14" NPS S-140  
ASME SA-376 TP316


Flued Head:

ASME SA-182 GR. F-316

TYPE III - 3

(RHR Supply) 1/Unit  
(RHR Return to Hot Legs) 1/Unit

FIGURE 4



Type III - 5 (Upper Head Injection)

2/Unit

REF: ML-1676-3.8

Process Pipe: 12" NPS S-140  
ASME SA-376 TP 316

Flued Head: ASME SA-182 GR F316

DUKE POWER COMPANY  
Request For Relief From  
Inservice Inspection Requirement

Station: McGuire

Unit: 1

Reference Code: ASME Boiler and Pressure Vessel Code, Section XI, 1971 Edition  
through Winter 1972 Addenda

I. Component for which exemption is requested:

a. Name and Identification Number:

Main Steam and feedwater systems  
See attached Figures 1, 2, 3, 4, 5, 6, 7, 8

b. Function:

Circulate secondary coolant

c. ASME Section III Code Class:

Class II

d. Valve Category: NA

II. Reference Code Requirement that has been determined to be impractical:  
Category CG, Item C2.1 of Table ISC-261, Volumetric Examination of piping  
circumferential butt welds. Due to presence of guard pipe, approximately  
16% of the feedwater and 75% of the Main Steam welds are inaccessible.

III. Basis for Requesting Relief

Reference Drawings - see figures 1 through 8

Material - Listed on reference figures

Estimate of Preservice Examination Performed - 0% on inaccessible portions  
100% on accessible portions

Original fabrication examination - 100% Radiography

Measures which would be required to make the areas accessible - Removal  
of the guard pipe

## DUKE POWER COMPANY


Request For Relief From  
Inservice inspection Requirement

- III. Basis for Requesting Relief (cont.)  
The guard pipe was designed and installed for pipe rupture and jet impingement protection required by NRC directives. Section XI requirements to inspect Class II piping systems had not been developed at the time of system design. Component integrity can be assured by examining the accessible welds (Section XI only requires examining 50% of the welds at structural discontinuities, and this number is further reduced by applying the multiple stream concept) and hydrostatic tests. The purpose of the guard pipe and support systems is to maintain plant safety in the unlikely event of system failure. We believe the extreme measures required to make the areas accessible without compensating increase in the level of quality assurance do not justify the high cost and loss of time.
- IV. Alternate Examination:  
No alternate examination is possible.

## V. Implementation Schedule:

Preservice examination has been completed on the accessible welds. Inservice examinations will be performed on the accessible welds as required by the Section XI specified by 10CFR50.55a paragraph (g).

REF: MC-1591-1.1



Process Pipe:


16"-18" NPS S-80  
ASME SA-106 GR B  
Seamless

Fittings:

ASME SA-234 GR WPB  
Seamless or EFW

Figure 1

REF: MC-1591-1.1



Process Pipe:

16"-18" NPS S-80  
ASME SA-106 GR B  
Seamless

Fittings:

ASME SA-234 GR WPB  
Seamless or EFW

FEEDWATER

Figure 2




Process Pipe:

16"-18" NPS S-80  
ASME SA-106 GR B  
Seamless

Fittings:


ASME SA-234 GR WPB  
Seamless or EFW



REF: MC-1591-1.1

Figure 3

REF: MC-1591-1.1



16"-18" NPS S-80  
ASME SA-106 GR B  
Seamless

Fittings:

ASME SA-234 GR WPB  
Seamless or EFW

FEEDWATER

Figure 4

Process Pipe:

32" NPS, M.W. 1.375"

34" NPS, M.W. 1.250", 1.75", 2.08"


ASME SA-106 GRC

Seamless

Fittings:


ASME SA-234 GR WPC

Seamless



REF: MC-1593-1.0

Figure 5



Process Pipe:

32" NPS, M.W. 1.375"  
 34" NPS, M.W. 1.250", 1.75", 2.08"  
 ASME SA-106 GRC  
 Seamless

Fittings:


ASME SA-234 GR WPC  
 Seamless

MAIN STEAM

REF: MC-1593-1.0

Figure 6

REF: MC-1593-1.0



Process Pipe:


32" NPS, M.W. 1.375"  
34" NPS, M.W. 1.250", 1.75", 2.08"  
ASME SA-106 GRC  
Seamless

Fittings:

ASME SA-234 GR WPC  
Seamless

MAIN STEAM

Figure 7



REF: MC-1593-1.0

Process Pipe:

32" NPS, M.W. 1.375"  
 34" NPS, M.W. 1.250", 1.75", 2.08"  
 ASME SA-106 GRC  
 Seamless

Fittings:

ASME SA-234 GR WPC  
 Seamless

Figure 8

DUKE POWER COMPANY  
Request For Relief From  
Inservice Inspection Requirement

Station: McGuire

Unit: 1

Reference Code: ASME Boiler & Pressure Vessel Code, Section XI, 1971 Edition  
through Winter 1972 Addenda

I. Component for which exemption is requested:

a. Name and Identification Number:

Main Steam System welded restraint attachments  
RIA through R8A      RIC through R8C  
RIB through R8B      RID through R8D

b. Function:

Wear pads welded to main steam piping encased by guard pipe

c. ASME Section III Code Class:

Class II

d. Valve Category:

NA

II. Reference Code Requirement that has been determined to be impractical:

Category C-C, Item C2.4 of Table ISC-261 surface examination of integrally welded support-to-pipe welds. Due to the presence of guard pipe the welded wear pads of 1a above are inaccessible.

III. Basis for Requesting Relief

Material - SA-515 Grade 70 plate or SA-155 KC70 pipe wear pads fillet welded to SA-106 Gr C main steam piping

Estimate of Preservice Examination Performed - 0%

Original Fabrication Examination - Magnetic particle surface examination  
Measures which would be required to make the areas accessible - removal of the guard pipe

Reference Drawing - Sketch attached.

## DUKE POWER COMPANY

Request For Relief From  
Inservice Inspection Requirement

## III. Basis for Requesting Relief (cont.)

The main steam guard pipe was designed and purchased before there was a Section XI requirement to inspect Class II components. These wear pads are only subject to compressive stresses. The welds have been verified defect free by original fabrication examination. Component integrity can be assured by inspecting similar system welds and hydrostatic tests.

## IV. Alternate Examination:




No alternate examination is possible.

## V. Implementation Schedule:

The system is installed and field hydrostatically tested. Inservice inspections will not be possible because of inaccessibility.



Typical Support Arrangements



REF: MC-1593-1.0

Welded Support Locations  
(Identical on all 4 Steam Generators)

DUKE PUMPER COMPANY  
Request For Relief From  
Inservice Inspection Requirement

Station: McGuire

Unit: 1

Reference Code: ASME Boiler & Pressure Vessel Code, Section XI, 1971 Edition  
through Winter 1972 Addenda

I. Component for which exemption is requested:

a. Name and Identification Number:

Feedwater system welded attachments, CF-H1 and CF-H2.  
See attached sketch.

b. Function:

Wear pads welded to feedwater piping encased by guard pipe

c. ASME Section III Code Class:

Class II

d. Valve Category:

NA

II. Reference Code Requirement that has been determined to be impractical:

Category C-C, Item C2.4 of Table ISC-261 surface examination of integrally welded support-to-pipe welds. Due to the presence of guard pipe the wear pads are partially inaccessible.

III. Basis for Requesting Relief

Material - CF-H1 and CF-H2 each consists of 4 segments of ASME SA-106 Gr. B pipe 3/8 in x 8 in. x 6 in fillet welded to ASME SA-106 Gr. B pipe.

Estimate of Preservice Examination Area Accessible - 35%

Original Fabrication Examination Performed - Magnetic particle  
surface examination

Measures which would be required to make the area accessible - Removal  
of the guard pipe

Reference Drawing - Sketch attached.

## DUKE POWER COMPANY

Request For Relief From  
Inservice Inspection Requirement

## III. Basis for Requesting Relief (cont.)

The feedwater guard pipe was designed and purchased before there was a Section XI requirement to inspect Class II components. The welds have been verified defect free by original fabrication examination. Component integrity can be assured by inspecting the 35% of the accessible area, inspection of similar system welds, and hydrostatic tests.

## IV. Alternate Examination:

No alternative examination is possible.



## V. Implementation Schedule:

The system is installed and field hydrostatically tested. The accessible areas will be examined in January 1979. Inservice examination of the accessible areas will be in accordance with the Section XI code required by 10CFR50.55a, paragraph g.



Attachment to

MC-1-031

Ref. Dwg. - MC 1591-1.1



Section A-A



Section B-B

Feedwater Welded Attachments