

LICENSEE EVENT REPORT UPDATE REPORT - PREVIOUS REPORT
DATE 11-30-78

CONTROL BLOCK: _____ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 N C B E P 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T
0 1 REPORT SOURCE L 0 5 0 - 0 3 2 4 7 1 1 0 1 7 8 8 0 3 2 1 7 9 9
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
0 2 During the rod block monitor (RBM) periodic test (P.T. 1.5PC), RBM Channel A was

0 3 found out of calibration. (Technical Specification 3.1.4.3).

0 4

0 5

0 6

0 7

0 8

0 9 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
R B 11 X 12 Z 13 I N S T R U 14 X 15 Z 16
9 10 11 12 18 19 20

17 LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
7 8 0 7 2 0 3 X 1
21 22 23 24 26 27 28 29 30 31 32

ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
E 18 X 19 Z 20 Z 21 0 0 0 0 N 23 Y 24 N 25 G 0 8 0 0 26
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
1 0 The RBM was out of calibration due to setpoint drift. The monitor was recalibrated

1 1 and returned to service. Frequency of calibration for the monitor will be increased

1 2 from once per year to twice per year. This action should prevent similar events from

1 3 occurring.

1 4

FACILITY STATUS % POWER OTHER STATUS (30) METHOD OF DISCOVERY DISCOVERY DESCRIPTION (32)
1 5 E 28 0 9 9 29 NA B 31 Periodic Test
8 9 10 12 13 44 45 46 80

ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)
1 6 Z 33 Z 34 NA NA
8 9 10 11 44 45 80

PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39)
1 7 0 0 0 37 Z 38 NA
7 8 9 11 12 13 80

PERSONNEL INJURIES NUMBER DESCRIPTION (41)
1 8 0 0 0 40 NA
7 8 9 11 12 80

LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION (43)
1 9 Z 42 NA 7 9 0 3 2 7 0 5 3 2
7 8 9 10 80