



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION IV
611 RYAN PLAZA DRIVE, SUITE 1000
ARLINGTON, TEXAS 76011

702RA

702RA

April 26, 1979

In Reply Refer To:

RIV

Docket No. STN 50-482/Rpt. 78-13

Kansas Gas and Electric Company
ATTN: Mr. Glenn L. Koester
Vice President-Operations
Post Office Box 208
Wichita, Kansas 67201

Gentlemen:

Thank you for your letter of March 22, 1979, in response to our letter dated February 16, 1979, and the attached Notice of Violation.

As a result of our review, we find that additional information is needed. Specifically, in your response to finding No. 4, "Failure to Complete User Tests Within Time Limits," you indicated that your constructor (DIC) and AE (Bechtel) regard the time limits of ASTM C-150 (paragraph 10-1977 edition) as a minimum, and you indicate that no violation (of procedures) has occurred. Since it is our position that the time limitations for testing are clearly stated in ASTM C-150, please provide the basis for your interpretation.

Sincerely,

W. C. Seidle, Chief
Reactor Construction and
Engineering Support Branch

7906050056