

15 MAIL

USNRC REGIONAL
TELEPHONE REPORT

19 JUN 5 P 4: 03

FACILITY: Sequoyah 1 & 2

DOCKET #: 50-327, 328

DATE: 6/4/79

TIME: 4:00 p.m.

LTC. OCC. #: SEQ CEB 79-20

SUBJECT: CDR - Reactor Vessel Insulation Supports

DESCRIPTION OF OCCURRENCE: The support structure for the thermal insulation

is not adequate to withstand the design seismic event. This is a

Westinghouse supplied item. The impact of the insulation on the

incore instrumentation nozzles exceeds the design allowable stresses.

Part 21 determination needed.

I informed them that North Anna first reported this August 3, 1978 and

TVA should inquire why Westinghouse did not inform TVA before June, 1979.

SIGNATURE

2339 20

3019 5/10

7906200372

OFFICIAL COPY

790299