

Alabama Power Company  
500 North 18th Street  
Post Office Box 2641  
Birmingham, Alabama 35291  
Telephone 205 323-5341

F. L. CLAYTON, JR.  
Senior Vice President



Alabama Power  
the southern electric system

April 27, 1979

Joseph M. Farley Nuclear Plant - Unit 2  
NRC Inspection of March 27-29, 1979  
File: A-35.10.03  
Log: 79-108

Mr. James P. O'Reilly  
U. S. Nuclear Regulatory Commission  
101 Marietta Street NW - Suite 3100  
Atlanta, Georgia 30303

Re: RII:MDH 50-364/79-6

Dear Mr. O'Reilly:

The inspection report transmitted by Mr. Murphy's letter of April 11, 1979, has been reviewed by all concerned parties and we do not consider any of the information contained therein to be proprietary.

We have taken the following action in response to the item noted in the inspection report:

5. Independent Inspection Efforts - Unit 2

Infraction 364/79-06-01 Improper Control of Revised Electrical Drawings

- 1) A. The cause of the subject discrepancy was that the drawings were inadvertently left in the electrical penetration room when personnel were dismissed due to cut back.
- B. The electrical department made a search of all buildings for void drawings and specifications, in order to meet the practices of controlling the retrieval of void drawings. The requirements of QCP 5.3.2.1, which requires that superseded drawings be stamped "Void" if maintained as a Work Record is being implemented.

19 MAY ~ A 9 : 21  
USNRC REGION II  
ATLANTA, GEORGIA

2348 277

7906220247


19050  
OFFICIAL COPY

April 27, 1979

Page 2

- 2) A. A new in-house procedure for controlling electrical prints has been completed as of February 2, 1979, and is being implemented as of this date.  
  
B. The Electrical Manager has instructed all field supervision on this subject and has explained the importance of keeping electrical documents under control and updated.
  
- 3) Full compliance has been achieved as of April 13, 1979, and electrical documents will be monitored in the future to assure compliance with applicable documentation control procedures.

Very truly yours,



F. L. Clayton, Jr.

*for*

FLC:CBSh

cc: Mr. M. D. Hunt

2348 278