

TEXAS UTILITIES GENERATING COMPANY

2001 BRYAN TOWER • DALLAS, TEXAS 75201

June 18, 1979
TXX-3002

R. J. GARY
EXECUTIVE VICE PRESIDENT
AND GENERAL MANAGER

Mr. W. C. Seidle, Chief
Reactor Construction & Engineering
Support Branch
U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
611 Ryan Plaza Dr., Suite 1000
Arlington, Texas 76012

Docket Nos. 50-445
50-446


COMANCHE PEAK STEAM ELECTRIC STATION
1981-83 2300 MW INSTALLATION
PIPE WALL THICKNESS
FILE NO. 10110

Dear Mr. Seidle:

On May 22, 1979, we verbally informed your Mr. R. G. Taylor that pipe wall thickness requirements established in the project piping specs may not have been adequately conservative to meet ASME code stress requirements.

We are continuing our investigation and evaluation and will notify you as soon as we have reached a conclusion.

Very truly yours,


R. J. Gary

RJG:dla

cc: NRC Region IV - (0 + 1 copy)

Director, Inspection & Enforcement - (15 copies)
c/o Distribution Services Branch, DDC, ADM.
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

2348 090

7906220 324