

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

C	I	G	A	E	I	H	2	(2)	0	0	0	0	0	0	0	0	0	0	0	(3)	4	1	1	1	1	(4)			(5)			
7	8	9					14	15											25	26								57	CAT	58		
		LICENSEE CODE						LICENSE NUMBER																		LICENSE TYPE						

CON'T

REPORT SOURCE L 6 0 5 0 0 0 3 6 6 7 0 2 1 4 7 9 8 0 2 2 8 7 9 9

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

At 2148 CST 2/14/79 while performing startup test procedure HNP-2-10925, MSIV closure, safety relief valves 2B21-F013 C and G failed to open with its 1090 Psig setpoints in the presence of a reactor high pressure of 1125 Psig. Safety relief valves C and G were declared inoperable and a maintenance request was initiated to replace C and G with new topworks of the same pressure setpoints. The other 9 safety relief valves were available at the time of the scram. This is a non-repetitive occurrence for Unit 2, but this event has repetitively occurred on Unit 1.

09		SYSTEM CODE C C		11	CAUSE CODE E		12	CAUSE SUBCODE B		13	COMPONENT CODE V A L V E S				14	COMP. SUBCODE X		15	VALVE SUBCODE B		16					
7	8	9	10		11		12		13					14		15		16								
17		LER RO REPORT NUMBER		EVENT YEAR 7 9		21	22	SEQUENTIAL REPORT NO. 0 2 4		24	26	OCCURRENCE CODE 0 3		28	29	REPORT TYPE L		30	REVISION NO. 0		32					
ACTION TAKEN A		18	FUTURE ACTION E		19	EFFECT ON PLANT C		20	SHUTDOWN METHOD Z		21	HOURS 0 0 0 0		22	ATTACHMENT SUBMITTED Y		23	NPRD-4 FORM SUB Y		24	PRIME COMP. SUPPLIER N		25	COMPONENT MANUFACTURER T 0 2 0		26
33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The cause for the apparent failure of the target rock Model 7567F, 6 x 10 two stage
1 1 | relief valves 2B21- F013 C (Serial #308) and G (Serial #310) is unknown. The top-
1 2 | works have been replaced. A followup report will be written when the investigation
1 3 | is completed on the removed topworks.

8 9 FACILITY STATUS 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

1 5 B 78 0 9 6 79 N/A C 31 Test of Data

ACTIVITY CONTENT
RELEASED OF RELEASE

1 6 2 23 2 34

AMOUNT OF ACTIVITY (35)
N/A

LOCATION OF RELEASE (36)
N/A

PERSONNEL EXPOSURES			DESCRIPTION	
NUMBER	TYPE			
17	000	37	Z	38
N/A				

PERSONNEL INJURIES				DESCRIPTION	
1	2	3	4	5	6
0	0	0	40		N/A

7		8		9		11		12	
1		G		Z		42		43	
TYPE		DESCRIPTION							
		N/A							

7 8 9 10
PUBLICITY DESCRIPTION (45) 7904090177 N/A
ISSUED N/A (44)
NRC USE ONLY

NRC USE ONLY

NAME OF PREPARER T. V. Greene, Supt. Plt. Eng. Services

PHONE

68 69
912-367-7781