

TEXAS UTILITIES GENERATING COMPANY

2001 BRYAN TOWER - DALLAS, TEXAS 75201

June 8, 1979

TXX-2997

R. J. GARY
EXECUTIVE VICE PRESIDENT
AND GENERAL MANAGER

Mr. W. C. Seidle, Chief
Reactor Construction & Engineering
Support Branch
U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
611 Ryan Plaza Dr., Suite 1000
Arlington, Texas 76012

Docket Nos. 50-445
50-446

COMANCHE PEAK STEAM ELECTRIC STATION
1981-83 2300 MW INSTALLATION
UNIT NO. 1 REACTOR VESSEL NOZZLE
WELD METAL DEFECTS
FILE NO. 10110

Dear Mr. Seidle:

On January 26, 1979, we verbally informed your Mr. W. A. Crossman of apparent weld metal defects in the shop weld between the Unit No. 1 reactor pressure vessel hot leg nozzle "C" and its safe end. We considered this "potentially" reportable under 10 CFR 50.55(e).

We are continuing our investigation and evaluation and will notify you as soon as we have reached a conclusion.

Very truly yours,

R. J. Gary
R. J. Gary

RJG:d1a

cc: NRC Region IV - (0 + 1 copy)

Director, Inspection & Enforcement - (15 copies)
c/o Distribution Services Branch, DDC, ADM.
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

2349 346

7906120208