



UNITED STATES NUCLEAR REGULATORY COMMISSION

REGION IV 611 RYAN PLAZA DRIVE, SUITE 1000 ARLINGTON, TEXAS 76012

May 16, 1979

Docket No. STN 50-482

Kansas Gas and Electric Company ATTN: Mr. Glenn L. Koester Vice President-Operations Post Office Box 208 Wichita, Kansas 67201

Gentlemen:

Enclosed is supplement AN to Preliminary Notification PNO-79-67, "Nuclear Incident at Three Mile Island," dated May 14, 1979.

Should you have any questions regarding this review, please contact this office.

Sincerely,

Reactor Construction and Engineering Support Branch

Enclosure: PNO-79-67AN

cc: w/enclosure:

Messrs. Nicholas A. Petrick, SNUPPS

D. T. McPhee, Kansas City Power and Light Company Gerald Charnoff, Shaw, Pittman, Potts & Trowbridge E. W. Creel, Kansas Gas and Electric Company

· IMMEDIATE PRELIMINARY NOTIFICATION

May 14, 1979

PPELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE == PNO-79-67AN (Corrected)

This preliminary notification constitutes summary information of an event of safety or public interest significance.

Facility: Three Mile Island Unit 2

Middletown, Pennsylvania (DN 50-320)

Subject: NUCLEAR INCIDENT AT THREE MILE ISLAND

Operational Status

- The average coolant temperature is being maintained at 170 degrees F
 by natural circulation. Pressure is about 650 psi. Steam is being
 admitted to the main condenser through the turbine bypass valves
 from the A Steam Generator. The highest incore temperature reading is 308 degrees F.
- 2. All four trains of the independent, additional charcoal filter system are presently operable. Normally three trains are operating at any one time to provide additional filtration for the entire gaseous effluent flow from Unit 2. Iodine concentrations in the gaseous effluent have been below instantaneous release limits and below detectable levels most of the time.
- Preliminary hydrostatic testing of the existing decay heat removal system ("A" and "B" loops) has been performed. Leaks have been identified and are being corrected.
- 4. The pressurizer has been taken "solid" periodicall" to obtain confirmatory information on pressurizer level and to check primary system leak rate.
- 5. Measurements of the liquid level inside containment is planned in the near future by measuring the hydrostatic head on the sump discharge piping using a recently installed Heise gage.

Environmental Status

Environmental radiation levels continue to be consistent with natural background levels. There were approximately four minor releases during the past week (May 7-13, 1979) associated with venting of the primary makeup tank and work on the new filter train system and monitors. During this period 14 24-hour continuous air samples and 27 air grab (1 to 2 hr.) samples were collected, and all were less than MDA. A goat milk sample taken on May 8, 1979 contained an I-131 concentration of 12 pCi/liter. The latest goat milk sample collected and analyzed on May 13 showed less than MDA for I-131 (F10 pCi/l). Grass samples taken at the goat farm showed I-131 levels less than MDA. Cow milk samples and grass samples from other locations show less than MDA levels for I-131. Ground surveys continued to show radiation to be at background levels. Aerial surveillance flights have not shown any levels of I-131 above MDA. Other Federal Agencies have not reported any positive values for samples taken during this period.

Contact: RCPaulus, IE x272	246; DThompson, IE x28487 -	
Distribution: Transmitte Chairman Hendrie	ed H St 4:05 Commissioner Bradford	e i chilb erev
Commissioner Kennedy	· Commissioner Ahearne	S. J. Chilk, SECY
Commissioner Gilinsky	ACRS	C. C. Kammerer, CA
Transmitted: MNBB will	P. Bldg 4:10	(For Distribution)
L. V. Gossick, EDO	H. R. Denton, NRR	J. G. Davis, IE
H. L. Ornstein, EDO		Region I 4:20 4:35
J. J. Fouchard, PA	R. C. DeYoung, NRR	Region II 4:25
N. M. Haller, MPA	R. J. Mattson, NRR	Region III 4:30
R. G. Ryan, OSP	V. Stello, NRR	Region IV 4:38
H. K. Shapar, ELD	R. S. Boyd, NRR	Region V
a. a. baopar, Em	SS Bldg 4:20	(MAIL)
	W. J. Dircks, NMSS	J. J. Cummings, OIA
IE (TMI) Site (F	S. Levine, RES	R. Minogue, SD
An an a second	Provide copy to STATE)	It is a section of
White House Situation Room	Middletown - TMI- Informat	ion Center)
Annual School Control of the Control		the said family and the said
EPA (Provide cop	ies to the Administrator a	nd the Operations Center)
DOE/EOC		
PEHA		
ERP (State of PA)		
DCPA		
HEW		
A CONTRACT OF THE PARTY OF THE		
Handcarry (FAA)		

IMMEDIATE
PRELIMINARY NOTIFICATION