

TERA

5005020582

REGULATORY DOCKET FILE COPY

MAR 25 1980

MEMORANDUM FOR: H. Silver, TMI-1 Restart Project Manager

FROM: R. Fitzpatrick, Power Systems/TMI Support Group

THRU: G. Mazetis, Section Leader, Reactor Systems Branch

SUBJECT: TMI-1 - MANUAL CONTROL OF PORV

On March 21, 1980 Scott Newbury and myself talked via telephone with Courtney Smythe of Met Ed on the above subject. The TMI-1 LOCA procedure, currently in-house for staff review, calls for an operator to go behind the main control panel for jumpering activities to allow manual opening of the PORV during a feed-and-bleed mode of cooling. We conveyed the unacceptability of this concept to Mr. Smythe. Mr. Smythe then informed us that Met Ed was already pursuing a modification for this that was scheduled for completion end of May 1980. Mr. Smythe committed to reflect this modification in the next amendment. This resolves our concern and we shall followup on the design change accordingly.

14

R. Fitzpatrick
Power Systems/TMI Support Group

cc: R. Vollmer
J. Collins
B. Boger
S. Newberry

DISTRIBUTION:
Central Files
NRR RF
PSB RF
R. Fitzpatrick RF

OFFICE ▶	PSB	RSB			
SURNAME ▶	RFitzpatrick:hlh	GMazetis			
DATE ▶	3/21/80	3/21/80			