

U.S. NUCLEAR REGULATORY COMMISSION
OFFICE OF INSPECTION AND ENFORCEMENT

REGION III

Report No. 50-237/78-26

Docket No. 50-237

License No. DPR-19

Licensee: Commonwealth Edison Company
Post Office Box 767
Chicago, IL 60690

Facility Name: Dresden Nuclear Generating Station, Unit 2

Inspection At: Dresden Site, Morris, IL

Inspection Conducted: October 23-25 and October 31-November 2, 1978

Inspectors: *J. A. Hind*
A. G. Finley 12/7/78

J. A. Hind
J. P. Patterson 12/7/78

Approved By: *J. A. Hind*
J. A. Hind, Chief 12/7/78
Safeguards Branch

Inspection Summary

Inspection on October 23-26 and October 31-November 2, 1978 (Report No. 50-237/78-26)

Areas Inspected: Material Control and Accountability including facility organization and operation; measurements and control; storage and internal controls; shipping and receiving; records and reports; inventory and inventory verification; and management of material control system. The inspection involved 45 inspector-hours onsite by two NRC inspectors.

Results: Of the seven areas inspected, no apparent items of noncompliance or deviations were identified in six areas; one apparent item of noncompliance/deficiency - failure to dispatch Forms NRC-741 on the same day material was shipped (Paragraph 7).

Details (Part 2.790(d) Information)

7901090401