

NOV 27 1978

APPENDIX A

NOTICE OF DEVIATION

Virginia Electric and Power Company

License No. NPF-4

Based on the results of the NRC inspection conducted on October 30 - November 3, 1978, certain of your activities appear to deviate from your commitments to the Commission as indicated below.

Licensee Event Report No. LER 78-063/03L-0, dated August 21, 1978, states that the particulate filter for RM-RMS-159 will be checked periodically to verify that it is operating properly, and that the charcoal filter will be changed periodically.

Contrary to the above, no periodic checks of the particulate filter or changes of the charcoal filter had been instituted as of November 2, 1978.

7901120176