



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

TIC
JFBA

MAY 30 1979

Docket No. 50-546
Docket No. 50-547

Public Service of Indiana
ATTN: H. A. Barker, President
and Chief Executive Officer
1000 East Main Street
Plainfield, IN 46168

Gentlemen:

This refers to the meeting conducted at your corporate offices in Plainfield, Indiana by Mr. G. Fiorelli and others of this office on May 15, 1979, for the purpose of discussing construction activities at the Marble Hill Nuclear Plant site with you and others of your corporate staff.

The enclosed copy of the report of the meeting identifies areas discussed.

No items of noncompliance with NRC requirements were identified as result of this meeting.

During this meeting we requested that you evaluate in-place Auxiliary Building concrete through nondestructive methods on a selective basis, to provide confidence that no internal voids or honeycomb are present in the completed structure.

In addition, we requested that you review the activities of the appropriate quality control groups to determine what changes are required to eliminate the deficiencies observed during recent inspections of concrete placement. We will review the results of your efforts during our next inspection involving concrete work.

In accordance with Section 2.790 of the NRC's "Rules of Practice," Part 2, Title 10, Code of Federal Regulations, a copy of this letter and the enclosed inspection report will be placed in the NRC's Public Document Room, except as follows. If this report contains information that you or your contractors believe to be proprietary, you must apply in writing to this office, within twenty days of your

7907240169

Public Service of
Indiana


- 2 -

MAY 30 1979

receipt of this letter, to withhold such information from public disclosure. The application must include a full statement of the reasons for which the information is considered proprietary, and should be prepared so that proprietary information identified in the application is contained in an enclosure to the application.

We will gladly discuss any questions you have concerning this inspection.

Sincerely,


James G. Keppler
Director

Enclosure: IE Inspection
Report No. 50-546/79-05
and No. 50-547/79-05

cc w/encl:
R. M. Brown, Construction
Project Superintendent
Central Files
Reproduction Unit NRC 20b
PDR Local PDR
NSIC
TIC
LeBoeuf, Lamb, Leiby & MacRae