

50-247  
DEC 0 8 1975

Robert W. Reid, Chief, Operating Reactors Branch #4, RL  
THRU: Thomas M. Novak, Chief, Reactor Systems Branch, TR

INDIAN POINT UNIT 2: REQUEST FOR CHANGING UNDERFREQUENCY TRIP OF THE  
REACTOR COOLANT PUMPS FROM 57.5hz TO 55hz (TAR-1847)

Via your memo of September 8, 1975, you requested an evaluation of  
Con Ed's proposed change of reactor coolant pump underfrequency trip  
setpoint.

Westinghouse has addressed this problem on a generic basis in topical  
report WCAP-8424, "Evaluation of Loss of Flow Accidents Caused by  
Power System Frequency Transients in Westinghouse PWR's". The generic  
problem is presently under review. Once we have completed the review  
of the generic problem, we will provide a date for completing the  
review of Con Ed's Indian Point 2 submittal.

Original signed by:

Zoltan R. Rosztoczy  
Section Leader  
Reactor Systems Branch  
Division of Technical Review

cc: V. Stello  
T. Ippolito  
A. Marinos  
W. Minners  
H. Ornstein  
P. Fling

DISTRIBUTION

NRR Reading  
~~Central Files~~  
RSB Reading

8111140162 710305  
CF ADOCK 05000247  
CF

OFFICE	TR:RSB	TR:RSB	TR:RSB			
SURNAME	Hornstein	ZRosztoczy	Novak			
DATE	12/3/75	12/5/75	12/5/75			