NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1	LICENSEE CODE: I L Q A D 1 (2)	LICENSE NUMBER: 0 0 0 - 0 0 0 - 0 0 0 (3)	LICENSE TYPE: 4 1 1 1 1 (4)	CAT (5)

CON'T

0 1	REPORT SOURCE: L (6)	DOCKET NUMBER: 0 5 0 0 0 2 5 4 (7)	EVENT DATE: 0 1 1 9 7 9 (8)	REPORT DATE: 0 3 0 9 7 9 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 While performing the Main Steam Isolation Valve Local Leak Rate Test, procedure

0 3 QTS 100-3, valves AO 1-203-1A, AO 1-203-2A, AO 1-203-1B, AO 1-203-2B, AO 1-203-1C,

0 4 AO 1-203-2C and AO 1-203-1D were found to have leakage rates in excess of the

0 5 11.5 SCFH allowable limit as specified by Technical Specification 4.7.A.2.i.c.

0 6

0 7

0 8

	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
0 9	C D (11)	E (12)	B (13)	V A L V E X (14)	F (15)	D (16)

(17) LER/RO REPORT NUMBER

EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
7 9	—	0 0 3	/	0 3	L	—	1

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
B (18)	Z (19)	Z (20)	Z (21)	0 0 0 0	N (23)	Y (24)	N (25)	C 6 6 5 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The 1-203-1D valve stroke was adjusted reducing the leak rate to 10.0 SCFH. The

1 1 valves on the A, B, and C steam lines were dismantled and repaired. Work included

1 2 lapping and machining of the main and pilot discs and seats. A subsequent test

1 3 showed corrected leak rates to be: 1-203-1A, 1.2 SCFH; 1-203-2A, 1.2 SCFH; 1-203-1B,

1 4 2.2 SCFH; 1-203-2B, 3.6 SCFH; 1-203-1C, 0.0 SCFH; 1-203-2C, 0.0 SCFH; and 1-203-1D, 10.0 SCFH

	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
1 5	H (28)	0 0 0 (29)	NA	B (31)	Local Leak Rate Testing

	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
1 6	Z (33)	Z (34)	NA	NA

PERSONNEL EXPOSURES

	NUMBER	TYPE	DESCRIPTION (39)
1 7	0 0 0 (37)	Z (38)	NA

PERSONNEL INJURIES

	NUMBER	DESCRIPTION (41)
1 8	0 0 0 (40)	NA

LOSS OF OR DAMAGE TO FACILITY (43)

	TYPE	DESCRIPTION
1 9	Z (42)	NA

7903290092

PUBLICITY

	ISSUED	DESCRIPTION (45)	NRC USE ONLY
2 0	N (44)	NA	

NAME OF PREPARER J. Kopacz PHONE 309-654-2241, ext. 247