



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

PRODUCTION DEPARTMENT

March 27, 1979

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street - Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly

Dear Sir:

SUBJECT: Grand Gulf Nuclear Station
File 0270/15525/15526
Potential Reportable Deficiency
No. 79/04 - Interim Report No. 1
AECM-79/26

On February 23, 1978, Mississippi Power & Light Company notified Mr. W. B. Kenna of your office of a potential reportable deficiency at the Grand Gulf Nuclear Station construction site. The deficiency concerns inadequate crimping in certain Power Generation Control Complex (PGCC) interconnecting cable pen connections supplied by the General Electric Company. We will determine reportability of this matter as defined by 10CFR50.55(e) and submit a final report by May 31, 1979.

Yours truly,

J. P. McGaughy, Jr.
Director of Power Production

JRF/EWC:pa

cc: Mr. N. L. Stampley
Mr. R. B. McGehee
Mr. T. B. Conner

Dr. Ernst Volgenau, Director *THIS COPY FOR*
Division of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

7904060262

Member Middle South Utilities System

*Boig
5/10*