

April 19, 1979

Mr. James P. O'Reilly, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Serial No. 190A
PSE&C/GLP:mac:wang

Docket No. 60-339

Dear Mr. O'Reilly:


On March 26, 1979, a report was made in accordance with the reporting requirements of 10CFR21 concerning Valve Limit Switch Actuating Arms.

All of the actuating arms on the valves of concern have been replaced and tested satisfactorily. The new arms are of one piece construction and they are more substantial than the original arm design.

We feel that the actuating arms are no longer a concern and that the new arms will provide reliable valve position information, therefore, this letter is considered to be our final report under the provisions of 10CFR21 and 10CFR50.55(e).

Should you require further information, please contact this office.

Very truly yours,


Sam. C. Brown, Jr.
Senior Vice President - Power Station
Engineering and Construction

cc: Mr. John G. Davis, Acting Director
Office of Inspection & Enforcement

✓ Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation

POOR
ORIGINAL

Bola
5/10

7904240454

5