4	LICENSEE EVENT REPORT
	CONTROL BLOCK: [] [] (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1	N C B E P 2 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 1 5 6 5 EICENSE CODE 14 15 ST CAT 58
CON'T 0 1 7 8	REPORT L 6 0 5 0 - 0 3 2 4 7 0 7 12 2 7 9 8 0 8 2 0 7 9 9 9
0 2	During normal surveillance of the control panel, the operator noticed that CO-CR 24
0 3	point 3 was printing erratically. This recorder monitors the hotwell condensate
0 4	outlet.
0 5	Technical Specifications 3.3.5.6, 6.9.1.9b
0 6	
0 7	
0 8	SYSTEM CAUSE CAUSE COMP. VALVE
0 9	$ \begin{array}{c ccccccccccccccccccccccccccccccccccc$
	17 LER/RO REPORT NO. SEQUENTIAL REPORT NO. CODE TYPE NO.
	ACTION FUTURE ACTION ON PLANT SHU DOWN HOURS 22 ATTACHMENT SUBMITTED FORM SUB. SUPPLIER MANUFACTURER Z 18 X 19 Z 20 Z 21 0 0 0 0 0 N 23 N 24 A 25 L 1 3 10 26 CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27
10	When the recorder was checked by I & C, it was found to be working properly and had
III	been for the past 48 hours. All wire connections were checked and found good. The
1 2	cell will be repacked during the next outage to prevent any possible leakage that
13	could cause erratic readings.
7 8	
1 5	ACILITY STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32 DISCOVERY DESCRIPT
	CTIVITY CONTENT LEASED OF RELEASE AMOUNT OF ACTIVITY (35) Z (33) Z (34) NA
1 7 8	PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39) O O O O ST Z (38) NA 9 00000000000000000000000000000000000
ī B	PERSONNEE INJURIES NUMBER DESCRIPTION (41) O O O O AO NA
1 9	2 9082704415
20	PUBLICITY SSUED DESCRIPTION 45 NAC USE ONLY
8	NAME OF PREPARED A. C. Tollison, Jr. 919-457-9521