

License No. DPR-50

APPENDIX A

NOTICE OF VIOLATION

Based on the results of the NRC inspection conducted on October 28-29, 1976, it appears that one of your activities was not conducted in full compliance with the conditions of your NRC Facility License No. DPR-50 as indicated below. This item is an Infraction.

1. 10 CFR 50, Appendix B, Criterion V, states, in part:
"Activities affecting quality shall be prescribed by documented . . . procedures . . . and shall be accomplished in accordance with these . . . procedures"
Paragraph 45.2.4.2 of licensee procedure 1104-45 titled "Fire Protection" states, in part: "Portable Fire Extinguishers . . . weighted and inspected monthly."

Contrary to the above, the monthly inspections of portable fire extinguishers had not been performed during February through June and September 1976.

1413 030

7910150 038

38