

NRR-DRMAPEm Resource

From: Lee, Samson
Sent: Friday, October 4, 2019 6:59 AM
To: Williams, Christian D:(Exelon Nuclear)
Subject: FitzPatrick Emergency amendment public conference call discussion points - 4

In the draft LAR dated October 2, 2019, Attachment 1, Section 2.0, the following is stated: “*Each Reserve Station Service Transformer (RSST) is fed from the **cross-tied** 115 KV power lines Lighthouse Hill Line #3 and Nine Mile Point Line #4. Each of these offsite 115KV sources are capable of providing power to either division 1 or 2 busses through the respective RSST.*”

Also in the JAF UFSAR, Section 8.3.2.4, the following is stated: “*Under normal operation, the **sectionalizing disconnect switches** and all breakers at both JAF Plant and NMPNS Unit 1 **are operated in the closed position**, thereby providing two sources of 115 kV power for the JAF Plant.*”

*During conference call yesterday, the licensee stated that 115 kV Motor Operated Disconnect (MOD) switch (cross-tie) between 115 KV power lines Lighthouse Hill Line #3 and Nine Mile Point Line #4 at JAF 115 kV switchyard is **normally kept open**.*

The LAR (and later UFSAR) should be revised to clarify that the above cross-tie (MOD switch) is normally kept open. Also, clarify that with the RSST 71T-3 under maintenance, whether this MOD switch would remain open.

Thanks,
Sam

Hearing Identifier: NRR_DRMA
Email Number: 242

Mail Envelope Properties (BL0PR0901MB318527BC45DEA7838F3F1AFB9A9E0)

Subject: FitzPatrick Emergency amendment public conference call discussion points - 4
Sent Date: 10/4/2019 6:59:10 AM
Received Date: 10/4/2019 6:59:00 AM
From: Lee, Samson

Created By: Samson.Lee@nrc.gov

Recipients:
"Williams, Christian D:(Exelon Nuclear)" <Christian.Williams@exeloncorp.com>
Tracking Status: None

Post Office: BL0PR0901MB3185.namprd09.prod.outlook.com

Files	Size	Date & Time
MESSAGE	1143	10/4/2019 6:59:00 AM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: