



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

February 5, 1979

Docket No. 50-247

Mr. William J. Cahill, Jr.
Vice President
Consolidated Edison Company of
New York, Inc.
4 Irving Place
New York, New York 10003

Dear Mr. Cahill:

By letter dated September 20, 1977, the Consolidated Edison Company responded to our letter of July 1, 1977 concerning High Pressure and Low Pressure Safety Injection (HPSI and LPSI) system throttle valves.

We have completed our review of that response and conclude that Section 4.5 of the Technical Specifications for Indian Point, Unit 2, which deals with the HPSI system, need not be changed to satisfy the intent of our July 1, 1977 letter.

Since the LPSI system throttle valves are not automatically actuated and are only used for throttling during the long-term recirculation mode, pre-specified valve positions are not appropriate.

In conclusion, we find your response acceptable and no further action is required.

Sincerely,

A. Schwencer, Chief

Operating Reactors Branch #1 Division of Operating Reactors

cc: See next page

Consolidated Edison Company of New York, Inc.

cc: White Plains Public Library 100 Martine Avenue White Plains, New York 10601

Joseph D. Block, Esq.
Executive Vice President Administration
Consolidated Edison Company
of New York, Inc.
4 Irving Place
New York, New York 10003

Edward J. Sack, Esq.
Law Department
Consolidated Edison Company
of New York, Inc.
4 Irving Place
New York, New York 10003

Anthony Z. Roisman Natural Resources Defense Council 917 - 15th Street, NW Washington, D.C. 20005

Paul S. Shemin, Esquire Assistant Attorney General State of New York Department of Law Two World Trade Center New York, New York 10047

Sarah Chasis, Esquire Natural Resources Defense Council 122 East 42nd Street New York, New York 10017

Theodore A. Rebelwoski USNRC P. O. Box 38 Buchanan, New York 10511