

TERA



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

February 8, 1979

Docket No. 50-219

Mr. I. R. Finfrock, Jr.
Vice President - Generation
Jersey Central Power & Light Company
Madison Avenue at Punch Bowl Road
Morristown, New Jersey 07960

Dear Mr. Finfrock:

Comments received on the draft evaluation of Systematic Evaluation Program Topic IV-1.A have been reviewed and the evaluation has been revised. The revised draft evaluation, copy enclosed, supersedes the evaluation issued by our letter dated August 17, 1978.

You are requested to examine the facts upon which the staff has based its evaluation and respond either by confirming that the facts are correct, or by identifying any errors. If in error, please supply corrected information for the docket. We encourage you to supply for the docket any other material related to this topic that might affect the staff's evaluation.

Your response within 30 days of the date you receive this letter is requested. If no response is received within that time, we will assume that you have no comments or corrections.

Sincerely,

Dennis L. Ziemann, Chief
Operating Reactors Branch #2
Division of Operating Reactors

Enclosure:
Topic IV-1.A

cc w/enclosure:
See next page

7903060477

Mr. I. R. Finrock, Jr.

- 2 -

February 8, 1979

cc w/enclosure:

G. F. Trowbridge, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

GPU Service Corporation
ATTN: Mr. E. G. Wallace
Licensing Manager
260 Cherry Hill Road
Parsippany, New Jersey 07054

Anthony Z. Roisman
Natural Resources Defense Council
917 15th Street, N. W.
Washington, D. C. 20005

Steven P. Russo, Esquire
248 Washington Street
P. O. Box 1060
Toms River, New Jersey 08753

Joseph W. Ferraro, Jr., Esquire
Deputy Attorney General
State of New Jersey
Department of Law and Public Safety
1100 Raymond Boulevard
Newark, New Jersey 07012

Ocean County Library
Brick Township Branch
401 Chambers Bridge Road
Brick Town, New Jersey 08723

K M C, Inc.
ATTN: Jack McEwen
1747 Pennsylvania Avenue, N. W.
Suite 1050
Washington, D. C. 20006

SYSTEMATIC EVALUATION PROGRAM

Topic IV-I-A: Operation with less than all loops in service

PLANT: Oyster Creek Nuclear Power Plant Unit No. 1

Discussion

The majority of the presently operating BWR's and PWR's are designed to permit operation with less than full reactor coolant flow. If a PWR reactor coolant pump or a BWR recirculation pump becomes inoperative, the flow provided by the remaining loop or loops is sufficient for steady state operation at some definable power level, usually less than full power.

Plants authorized for long term operation with one reactor coolant pump out of service have submitted, and the staff has approved, the necessary ECCS, steady state, and transient analyses. The remaining PWR and BWR licensees have Technical Specifications which require reactor shut-down within 24 hours if one of the operating loops becomes inoperable and cannot be returned to operation within the time period.

Evaluation

The docketed material for Oyster Creek has been reviewed with respect to operation with less than all loops in service. Oyster Creek is a five loop General Electric design Boiling Water Reactor (BWR). In a submittal dated February 5, 1976, Jersey Central Power & Light Company (JCP&L) presented an analysis for operation with a single recirculation pump inoperable. The analysis supported n-1 loop operation and concluded that ECCS analyses would not be affected provided that the inoperable pump was not isolated from the system.

The NRC staff reviewed and approved the February partial loop submitted in a safety evaluation (dated February 24, 1976). In addition the staff issued Technical Specification 3.3.F.1, 3.3.F.2, and 3.3.F.3 which state that operation is permitted with one inoperable recirculation loop provided that the inoperable loop is not isolated from the reactor system.

Based on the information reviewed we conclude that Topic IV-I-A: Operation with less than all loops in service at Oyster Creek is acceptable and complete requiring no facility or Technical Specification changes.