

78003

TELEPHONE REPORT

Hdqtrs. PDR

FACILITY: Shearon Harris Unit 1

DOCKET NO. 50-400

DATE: October 31, 1978

TIME: 3:20 pm

LIC. OCC. NO.:

SUBJECT: Potential CDR - Water Membrane Leakage in Unit 1 Containment

Call was received from N. J. Chiangi at Corp. Offices of CP&L

DESCRIPTION OF OCCURRENCE: Approximately 1500 gallons of water have been pumped from 4 sumps for unit 1 containment since October 4, 1978. It is not known if the accumulation is ground water or from concrete curing activities. If determined reportable 30-day report will follow.

79 03220 250

SIGNATURE