

ENCLOSURE 1

Omaha Public Power District
Fort Calhoun Station, Unit 1
Docket No. 50-285

NOTICE OF VIOLATION

Based on the results of an NRC inspection conducted January 22-24, 1979, it appears that certain of your activities were not conducted in full compliance with the NRC requirements as indicated below:

Appendix B, 10 CFR 50, Criterion V, requires that activities affecting quality shall be prescribed by documented procedures and shall be accomplished in accordance with these procedures. This requirement is incorporated in Section 17.5 of the OPPD Quality Assurance Program.

Surveillance test procedure ST-ICI-2, Incore Detector Alarm Limits, requires verification that the incore detector high alarm limits are less than or equal to the calculated alarm limits.

Contrary to the above, nine incore detector high alarm limits were not verified to be less than or equal to the calculated alarm limits during the performance of ST-ICI-2 on January 3, 1979, and eight of this nine had high alarm limits which were greater than the calculated alarm limits.

This is an infraction.

7903150186